



ADDENDUM 01

Project: Upstate – Library (IRC) Fire Sprinkler & Upgrades

Owner: USC Upstate

JCS Project #: 18104

State Project #: H34-9517

Date: 3/7/2019

GENERAL:

1. The list of attendees from the non-mandatory Pre-Bid Conference on March 14, 2019, are included in this addendum.
2. The last day for questions to the Architect is close-of-business, Tuesday, March 19, 2019.
3. A site visit for interested contractors is scheduled for Tuesday, March 19, between the hours of 8:00 am to 5:00 pm. Coordinate site visits with Cody Godfrey, Project Coordinator with USC Upstate, (864)-921-0077.

SPECIFICATIONS:

1. **Section 09 5123, Paragraph 2.2.A.1.** Revised to read “Armstrong #1728A, 24x24x5/8” Fine Fissured / HumiGuard Plus with minimum .55 NRC. Use Armstrong Prelude #7301 HD Grid and #7800 Wall Molding. Armstrong BERCClips must be used on all perimeter tees. Maintain required clearance between perimeter tees and wall molding per manufacturer's written instructions.
2. **Section 09 5123, Paragraph 2.2.A.2.** Delete paragraph in its entirety.
3. **Section 09 5123, Paragraph 2.2.B.** Delete paragraph in its entirety.

DRAWINGS:

1. **Sheet FP100, General Notes.** Add General Note #13 to read “ALL SPRINKLER WORK IN THE 2ND FLOOR CLASSROOM SPACES MUST BE COMPLETE AND OCCUPIABLE PRIOR TO AUGUST 13 TO ALLOW CLASSES TO RESUME FOR THE FALL SEMESTER. THESE CLASSROOMS INCLUDE THE FOLLOWING ROOM NUMBERS: 225, 226, 227, 228, 234, 236, 238, 240, 246, 247, 248, 249, 250, 251, AND 252. COORDINATE SEQUENCING OF WORK ACCORDINGLY.”

END OF ADDENDUM

**University of South Carolina
Non Mandatory Pre Bid Sign In Sheet**
Spartanburg SC

Project Name: Upstate-Library (IRC) Fire Sprinkler & Upgrades
Project Number: H34-9517
Pre Bid Date & Time: March 14, 2019 11:00AM 155 American Way Conf Rm 110

SWMBE Contractor indicate Below	Name	Company Name	Address	Phone #	Email
S W M B E	Scott Wilson Scott Wilson	Tom Scot	P.O. 27105 Greenville, S.C.	864 284-9402	Swilson@tomscot.com
S W M B E	Cod, Godfrey	FMC	800 University WAY	503-5500	Godfrey@univofsc.edu
S W M B E	DARRYN BOURKNIGHT	JCS	412 MEETING ST W. COLA	803 791-1020 29169	dbourknight@jcsarchitects.com
S W M B E					
S W M B E					
S W M B E					
S W M B E					
S W M B E					
S W M B E					

****By signing this sheet you agree to receive information electronically.