



ADDENDUM 02

Project: Upstate – Library (IRC) Fire Sprinkler & Upgrades

Owner: USC Upstate

JCS Project #: 18104

State Project #: H34-9517

Date: 3/22/2019

SPECIFICATIONS:

No changes.

DRAWINGS:

1. **Drawing 1-A300.** REIVSE the note reading “REMOVE EXISTING VCT AND RUBBER BASE WITHIN RISER ROOM” to read “DUE TO THE SUSPECTED PRESENCE OF ASBESTOS CONTAINING MATERIAL IN EXISTING FLOOR TILE MASTIC, THE METAL STUD FLOOR TRACK SHALL BE SHOT INTO THE FLOOR WITH POWDER-ACTUATED FASTENERS, RATHER THAN DRILLED, AS REQUIRED BY USC ENVIRONMENTAL SAFETY.”

END OF ADDENDUM