

**REBID USCA Pacer Downs Swimming Pool Resurfacing
Project Number FP00000217**

Addendum Number One

Date: May 17, 2019

From: Aimee B. Rish 
Procurement Specialist

To: All Bidders

The following items add to, modify, clarify, or otherwise alter the Drawings and/or specifications and will become a part of the Contract Documents. Where a portion of the Drawings and/or specifications is added to, modified, clarified, or otherwise altered, the portion not so affected shall remain. Bidder shall include all effects that these items may have on his proposal.

Acknowledge receipt of this addendum in the space provided on the Bid Form. Failure to do so may subject a Bidder to disqualification.

General:

1. Deadline for questions is May 21st at 12:00PM (noon). Please send all questions via email to Brian Enter, P.E. His email address is located on the SE311-Invitation for Minor Construction Quotes.
2. If needed, the last addendum will be issued no later than 3:00PM on Thursday, May 23rd.
3. DHEC approved the Change Order Request submitted by USC Aiken (Permit #02-054-1B). Attached are DHEC Special Conditions that apply to this project, and become part of the Contract Documents.

Attachment: DHEC Special Conditions

END OF ADDENDUM NUMBER ONE



**BUREAU OF WATER
POOL INTERIOR RESURFACING**

April 25, 2019

Change Order Request, Permit #: 02-054-1B (UNIVERSITY OF SOUTH CAROLINA AIKEN
PACER DOWNS)
Aiken County

Special Conditions:

1. Water line depth markers shall be provided on the vertical pool wall at a maximum and minimum point and at no more than two (2) foot intermediate increments of depth. Depth markers must be spaced at not more than twenty five (25) foot intervals on center, as measured around the perimeter of the pool. Depth markers must be in numerals and letters of four (4) inch minimum height and of a light background. A total of at least twelve (12) inches of white background tile must be included as part of each depth marker. The numerals and letters should be of a dark contrasting color with the background tile. Depth markers must be on both sides and ends of the pool and must be accurate to within 3 inches at normal operating level. The abbreviation "FT" or the word "FEET" must be included. Waterline tile must be of six (6) inch frost-proof tile or similar which is capable of withstanding repeated brushing and placed at the normal water surface.
2. On both steps and seats, a **non-slip** black or dark tile shall be provided on the front edge of each horizontal tread and seat. The edge stripe shall be a minimum of two (2) inches wide and must be provided the entire length of each step and seat. The step edge stripe must start with 1 inch from the edge of the step. Also, all type "A" and "B" facilities must provide the required "NO STEP" tiles on all seats.
3. Pools that exceed depths of five feet-six inches (5'-6") must incorporate a permanent **non-slip** black or dark color tile stripe on the walls and floor to mark the transition point. Transition break tile shall be four (4) to six (6) inches wide, of a dark color or black, and be non-slip. A lifeline with floats must be placed one (1) to two (2) feet on the shallow side of the breakline tile or at the 4'-6" depth location when there is no slope change.
4. Any "Figure 4" handrails shall be replaced with a handrail that anchors into the deck and the bottom step. Handrails must be of the removable type, but secured tightly in place when the pool is in operation.
5. The pool's interior finish must be moderately smooth, non-slip white or light colored water-proof finish, which will withstand repeated brushing, scrubbing and cleaning procedures. The surface shall be prepared, and material applied, in accordance with manufacturer recommendations. Colors must have a reflectance of 55% or greater.
6. One handrail must be provided for each 10 feet of step length or major fraction thereof (i.e., 2.5 feet) and their locations must be evenly spaced.
7. If racing lanes are to be provided they must be a minimum width of six (6) inches and a maximum width of twelve (12) inches. The construction must be of a dark colored non-

slip tile. Also, if wall targets are included they must be dark colored and non-slip.

8. Although not mandatory at this time, the Department recommends separating kiddie pools from main pools and placing them on a separate recirculation system. A change order is required for such work.
9. If a single main drain exists, then at least two main drains must be provided and interconnected with a "tee" fitting between the drains. Outlet grates must be anchored with corrosive resistant screws that cannot be removed without the use of tools and openings shall not be greater than one-half (1/2) inch. **Any main drain installation must be submitted under a separate change order.**
10. Please be advised that additional permits may be required prior to construction (e.g. Bureau of Air Quality, stormwater, etc.).
11. Any projects costing five thousand dollars (\$5,000) or more must be performed by a contractor who has been issued a public swimming pool contractor specialty license in accordance with the South Carolina Department of Labor, Licensing and Regulation.
12. **When the work is completed, contact Jessica A Fuller, of the Aiken EA Office at 803-642-1637 to schedule an inspection. She should be notified at least three (3) days prior to the desired inspection date.**
13. This change order is valid for one year from the approval date.

cc: UNIVERSITY OF SOUTH CAROLINA AIKEN PACER DOWNS
Aiken EA Office

tss