

Responsive People. Real Partners.

Architects Engineers Planners Constructors

1301 Gervais Street Suite 1300 Columbia, SC 29201 ▶ 803.799.6502
▶ 803.799.2014
₩www.pondco.com

# Addendum #3

DATE:	02/05/2020	PROJECT	USC FY20-21 CESC Gambrell 153 Auditorium
		NAME/NUMBER:	
			H27-Z407 50003375-2

This addendum modifies the Drawings and Specifications of the above-referenced project dated January 15, 2020. Changes noted herein will become part of the Contract. Except as noted herein, original drawings and any previous addendum(s) will apply.

# SPECIFICATIONS:

1. None

### DRAWINGS:

1. None

# QUESTIONS:

- 1. Question: What are the specs for the fabric covering the speakers in ALT1?
  - a. Response: Fabric for Alternate #1 to match the fabric utilized for the soundabsorbing ceiling units, as shown on detail A1, sheet A-301, specification 098436. Color to be selected by Architect.
- 2. Question: Can you please clarify that the housing and wiring will remain existing for the downlights and that only trims will be replaced. If housing and/or wiring are to be replaced is there access above the ceiling panels to properly complete these tasks?
  - a. Response: Entire downlight assemblies are specified as such on lighting fixture schedule and the intent is a complete replacement of recessed downlights. Due to the varying angle of slope reflectors required for each row of downlights, different fixture types were used (DA, DB, DC, etc.). Contractor shall order correct angle of slope adapter for each fixture type. The Contractor may use existing reflectors if new LED light engine and rough-in mate exactly with existing reflectors. One mockup shall be assembled for Engineer's approval before proceeding with entire replacements. There is a network of catwalks above the architectural cloud ceiling where downlights can be easily accessed for replacement. All existing downlights can be accessed above and below ceiling.
- 3. Question: If the low bidder of chairs has the same chair in another classroom on USC campus will they still need to provide an additional sample?
  - a. Response: The University of South Carolina will allow an installed sample if it is easy to access and within the Columbia area.

# ATTACHMENTS:

1. None

END OF ADDENDUM #3