

Addendum Two

September 11, 2019

NOTE: The following amendments, additions, and deletions shall be made to the Construction Documents and Contract Documents. Insofar as those documents are at variance with this Addendum, this Addendum shall govern.

Clarifications

- | <u>Item No.</u> | <u>Description</u> |
|-----------------|--|
| 1. | The bid date will be POSTPONED to Wednesday September 18, at 2:00 PM. |
| 2. | <u>Clarification:</u> The asbestos survey is in process. Survey will be available for contractor prior to work starting. Any abatement required will be performed by USC Upstate outside of the contractor's scope of work. Abatement is not included in the contractor's bid. |
| 3. | <u>Clarification:</u> Chapter 1 inspections are required but will be furnished by USC. The light test of the hood ductwork will be by the Chapter 1 inspector. |
| 4. | <u>Clarification:</u> The startup and testing of the hood systems will be included as part of the hood package and provide by the contractor. |
| 5. | <u>Clarification:</u> Fire Alarm connections to the hood are included as part of the Electrical scope of work. |
| 6. | <u>Clarification:</u> The Architectural Drawings are provided for reference only. All Architectural work is provided under a separate contract. This contractor is responsible for coordinating with the Architectural contractor for completion of the scope of work. |

Drawings

- | <u>Item No.</u> | <u>Description</u> |
|-----------------|---|
| 1. | <u>Revision:</u> Reference Drawing E2 Electrical Renovation Plan. The existing exterior light fixture will need to be shifted to coordinate with the new Kitchen Exhaust Fan. |

END OF ADDENDUM