



ADDENDUM NO.: FOUR DATE: 19 March 2014

PROJECT TITLE: **Indoor Practice Facility Construction**
University of South Carolina
Columbia, South Carolina

PROJECT NO.: State #H27-6090-MJ WTS No. 12710

WRITTEN BY: Gene Bell, AIA, LEED-AP

TO: Prospective Bidders / Plan Holders

This addendum is issued pursuant to Article 1.1.1 of the AIA General Conditions of the Contract (A201) in connection with the revision of Bidding Documents which have been previously issued.

Addenda are issued prior to execution of Contract. All instructions contained herein shall be reflected in the Contract Sum and this Addendum will be made a part of the Contract Documents, if, as, and when a Construction Contract is awarded.

This Addendum forms a part of the Contract Documents and modifies the original documents dated February 5, 2014, as noted below. Acknowledge receipt of this Addendum in this space provided on the Bid Form. Failure to do so will subject the Bidder to disqualification.

This Addendum consists of 1 pages and no attachments.

A. CLARIFICATIONS - None

B. REVISIONS TO PREVIOUS ADDENDA: None

C. REVISIONS TO THE PROJECT MANUAL:

1. SECTION 055110 METAL STAIRS AND CATWALKS

- a. Delete paragraph 1.2, A, 4 and delete paragraph 2.7 in its entirety. Stairs to have cable railings as specified in Section 057300 and as detailed on the drawings.

2. SECTION 099100 PAINTING

- a. At paragraph 3.7, B, delete the words "and hollow metal" and replace the word "Latex" with "Acrylic"
- b. Replace paragraphs 3.7, B, 2 and 3 with the following:
 - "2. 2nd Coat: S-W Pro Industrial Waterborne Acrylic Dryfall Semi Gloss
 - 3. 3rd Coat: S-W Pro Industrial Waterborne Acrylic Dryfall Semi Gloss(5.8 mils wet, 2.3 mils dry)"
- c. Add paragraph 3.7, D, as follows:
 - "D. Hollow Metal: Semi-Gloss Paint (primer and 2 finish coats)
 - 1. 1st Coat: S-W Pro Industrial Pro Cryl Universal Primer, B66-310 Series (5-10 mils wet, 2-4 mils dry)
 - 2. 2nd and 3rd Coat: S-W Pro Industrial PreCatalyzed Waterbased Semi-Gloss Epoxy (4 mils wet, 1.5 mils dry)

D. REVISIONS TO DRAWINGS:

- 1. Sheets S309 and S310: Add the following note to the drawings for the steel shown between column lines M and N and between lines E and F and North of column line 12.1 : "All exterior exposed steel, including grating to be galvanized and receive a high-performance coating."

END OF ADDENDUM