

University of South Carolina

Project Name: USC Upstate Chiller Replacement at Palmetto House
Project# H34-I386 50003402-2

Addendum NO. 2

DATE: October 2, 2020

FROM: PERITUS ENGINEERS & ASSOCIATES, INC.

TO: ALL BIDDERS

The following items add to, modify, clarify, or otherwise alter the Drawings and/or specifications and will become a part of the Contract Documents. Where a portion of the Drawings and/or specifications is added to, modified, clarified, or otherwise altered, the portion not so affected shall remain. Bidder shall include all effects that these items may have on his proposal.

Approvals

1. *Johnson Controls* Model "YVWA" water-cooled chiller with helical rotary compressors is APPROVED subject to compliance with project specifications for performance, electrical and physical characteristics.

END OF ADDENDUM NO. 2