



## Addendum Number Three

**Date of Issue:** 08/20/19

**Project:** Re-Bid USCA E-Sport/LAN Center FP00000231

**State Project Number:** FP00000231

### **TO: ALL BIDDERS OF RECORD**

This addendum modifies the Contract documents only in the manner and to the extent stated herein and shown on any accompanying drawings and will become part of the Contract Documents. Except as specified or otherwise indicated by this Addendum, all work shall be in accordance with the basic requirements of the Contract Documents.

BIDDERS SHALL ACKNOWLEDGE RECEIPT OF ADDENDUM IN THE SPACE PROVIDED ON THE BID FORM. FAILURE TO DO SO MAY CONSTITUTE A REASON TO REJECT THE BID.

This Addendum consists of two (2) pages including the following:

#### **I. Enclosures:**

NOT USED.

#### **II. General Information: Questions and Answers**

##### **1. 1" CONDUIT ABOVE ACCESSIBLE CEILING:**

Where hard ceilings exist, conduit shall go from device back to feeding source. Where accessible ceiling is available and a data outlet might be shown, it will go to 1' above accessible ceiling and turn 90. Cable is by others. EC is to provide the infrastructure as mentioned above.

##### **2. SURFACE RACEWAY:**

All devices (receptacles and data locations) are in the surface raceway. Walls are not to be cut into unless approved by the architect.

##### **3. MC CABLE:**

Where accepted as a VE by owner, MC is acceptable if a credit is issued to the owner. Otherwise conduit is required to be in the space.

#### **III. Changes to the Specifications:**

NOT USED.

**IV. Changes to the Drawings:**

NOT USED.

**V. Prior Approvals**

NOT USED.

END OF ADDENDUM THREE