



FEBRUARY 19, 2019
USC CLASSROOM ENHANCEMENTS 2019
FOR COKER 510
PROJECT# 50003348-2,H27-Z341

ADDENDUM #5

TO: ALL HOLDERS OF RECORD OF CONTRACT DOCUMENTS

Acknowledge receipt of this addendum by inserting its number and date in the bid form. Failure to do so may subject bidders to disqualification. This addendum forms a part of the Contract Documents.

The attached noted items are corrections, additions, or deletions to the Contract Documents, as noted:

ATTACHMENTS

CE Venders List

GENERAL NOTES

1. Clarification: 12 6100 – FIXED AUDIENCE SEATING Remove H & I for the flowing section. This information is given earlier in the section.
 - a. PART 2 PRODUCTS Sub paragraph 2.02 MATERIALS sub paragraph H Remove H.
“Seat Back: Manufacturer: Mayer Fabrics-Woven Connections; Name: Glacier Malibu WC718-024; Content: 100% Polyester; Width: 54”
 - b. PART 2 PRODUCTS Sub paragraph 2.02 MATERILAS sub paragraph I Remove I.
Seat Pan: Manufacturer: ARCOM; Name: Bronco; Color: Seafoam #7 (of 23 colorways)AC-69366; Content: 100% Polyurethane face and 100% Polyester Knit back; Finish: Wipeout/Aegis; Width: 54”; Application: Upholstery, Wallcovering, Panel”
2. Clarification: to DRAWING E101
 - a. In Note 3, add the following sentence, “Existing lighting and dimmer switches are 277v.”
 - b. In Note 7, change wording from “... cracked prismatic lenses ...” to “cracked and water stained prismatic lenses...”.
 - c. In Note 8, add sentence at end that reads, “Replace existing ceiling tiles and cut new openings for downlight reflectors.”



1310 Lady Street, Suite 204
Columbia, SC 29201
O: 803-376-6044
www.bstongroup.com

- d. Add Note 12 that reads, "Contractor shall protect existing fire alarm indicating device during construction. Remove from ceiling tile maintaining connectivity, bag during renovation, and re-install in new ceiling tile."

SPECIFICATIONS

<u>Item No.</u>	<u>Description</u>
1.	None

DRAWINGS

1.	None
----	------

Vendor Contact List*:

*For reference only.

SEATING:

Basis of Design – Irwin

Gerry Deas
Dan Deas & Associates
gerrydeas@msn.com
704-302-6919 Mobile

DOORS (per Architect):

William Hunter
Cook and Boardman
(803) 960-7660

AUDIO/VISUAL EQUIPMENT:

By U of SC UTS-A/V Department

FLOORING:

Basis of Design – Tate Flooring

Scott Miller Irvine Access Floors PH: (919)-790-0991

Melissa Wilson Sears Contracting PH: (919)-754-0750