

BURDETTE ENGINEERING, INC.

USC-UPSTATE ELEVATOR RECALL UPGRADE CONTROL, MEDIA & LIBRARY BUILDINGS Addendum No. 2

April 3, 2014

The following items shall be incorporated into the bid documents:

1. Ref. Drawing E1.1:
 - a. Delete all elevator modifications to the Media Building Elevator from the scope of work.
 - b. The scope of work for the Library Building shall include both Phase I Emergency Recall Operation and Phase II Emergency In-Car Operation. Installation of these operations shall include all modifications to the controller, wiring to the elevator car, installation of fire recall switch at the designated level and the fire operation switch in the control panel. All work shall conform to the ASME A17.1/CSA-B44 current edition. Contractor shall include all permitting requirements from SCLLR.
2. Work schedule shall be coordinated with Owner and shall be scheduled after May 2014 graduation. The Library will be occupied during this period.
3. Provide record drawings of all changes to the existing system wiring diagrams and copies of all inspections by LLR.

END OF ELECTRICAL ADDENDUM No. 2

File: 13860C-2