



SURVEY DATE: 11/30/2020

INSPECTOR #: ANTONIO THOMPSON (GR00052)

SCOPE: THE FOLLOWING SURVEY WAS PERFORMED IN PREPARATIONS TO REPLACE ALL THE SEALANT JOINTS ON THE EXTERIOR BUILDING ENVELOPE OF CAPSTONE. THIS INCLUDES SEALING ALL GLASS TO METAL, METAL TO METAL, METAL TO CONCRETE, AND CONCRETE TO CONCRETE.

ASBESTOS SECTION:

WHITE CAULK (CONCRETE TO METAL): POSITIVE FOR ASBESTOS (PLEASE SEE LINE 1 INSPECTOR NOTES).
BROWN CAULK (METAL TO METAL): NEGATIVE FOR ASBESTOS
BROWN CAULK (METAL TO GLASS): NEGATIVE FOR ASBESTOS
WHITE CAULK (CONCRETE TO CONCRETE): NEGATIVE FOR ASBESTOS

INSPECTOR NOTES:

1. WHITE CAULK (CONCRETE TO METAL) IS POSITIVE FOR ASBESTOS. PLEASE CONSULT WITH A LICENSED ASBESTOS ABATEMENT CREW IF WORK ACTIVITIES CALL FOR DISTURBANCE OR IMPACT TO THIS MATERIAL.
2. IF A BUILDING MATERIAL IS NOT LISTED, DO NOT ASSUME THAT IT DOES NOT CONTAIN ASBESTOS. IT MIGHT NOT HAVE BEEN TESTED. FOR FURTHER INFORMATION, PLEASE CONTACT THE USC HAZMAT PROGRAM.
3. IF YOU ENCOUNTER ANY OTHER MATERIALS IN PLACE AND DEEM THEM SUSPECT FOR ASBESTOS AND/OR LEAD, PLEASE STOP WORK AND CONTACT THE ASBESTOS PROGRAM MANAGER FOR FURTHER TESTING OR ABATEMENT.
4. PLEASE NOTE THAT THE MATERIAL QUANTITY PROVIDED ON THE FIELD SHEET IS ONLY AN ESTIMATE FOR SAMPLING PURPOSES. THE QUANTITY SHOULD BE FIELD VERIFIED FOR ALL OTHER PURPOSES INCLUDING ABATEMENT. THIS SURVEY IS ONLY VALID FOR THE DESIGNATED AREA(S)/LOCATION(S) TESTED IE: (039 CAPSTONE HOUSE EXTERIOR ENVELOPE).

09-SEP-16 ASBESTOS SUMMARY FOR CAPSTONE (039) – SEPTEMBER 2016

ASBESTOS HAS BEEN FOUND IN THIS BUILDING. IF DISTURBED, ASBESTOS MAY BE HARMFUL TO YOUR HEALTH.

PLEASE DO NOT DISTURB THE FOLLOWING MATERIALS IN THIS BUILDING AS THEY HAVE BEEN FOUND TO CONTAIN ASBESTOS.

- JOINT COMPOUND / SHEETROCK
- FIREPROOFING
- CEILING TILES (DUE TO FIREPROOFING)
- TEXTURED CEILING MATERIAL

IF A BUILDING MATERIAL IS NOT LISTED, DO NOT ASSUME THAT IT DOES NOT CONTAIN ASBESTOS. IT MAY NOT HAVE BEEN TESTED.

FOR FURTHER INFORMATION, PLEASE CONTACT THE USC HAZMAT PROGRAM.