

ADDENDUM NUMBER TWO
for
University of South Carolina - Coker 7th Floor Pharmacy Renovation-Mechanical
State Project Number: BC00433223 Project

COLUMBIA, SOUTH CAROLINA
PREPARED BY: Michelle Adams, Procurement Manager
DATE OF ISSUE: September 27, 2013
TO: ALL BIDDERS OF RECORD

The following items shall take precedence over the drawings and specifications for the above named project and shall become a part of the contract documents. Where any item called for in the specifications, or indicated on the drawings, is not supplemented hereby, the original requirements shall remain in effect. Where any original item is amended, voided or superseded hereby, the provisions of such item not specifically amended, voided or superseded shall remain in effect.

BIDDER SHALL ACKNOWLEDGE RECEIPT OF ADDENDUM IN THE SPACE PROVIDED ON THE BID FORM. FAILURE TO DO SO MAY CONSTITUTE AN INFORMALITY IN THE BID.

This addendum consists of 2 pages and the following attachments:
DRAWING M2.7

I. SPECIFICATIONS

15810 - Change paragraph 3.03.A.2 to read:

"2. Exhaust: Steel unless noted otherwise on drawings."

II. DRAWINGS

See attached revised drawing for M2.7

