

University of South Carolina  
Coker- Seventh Floor Renovation-Plumbing  
BC00433273

Addendum One  
January 30, 2014

NOTE: the following amendments, additions and deletion shall be made to the IDC Request for Quote form for the above mentioned project. Insofar as those document are at variance with this Addendum this Addendum shall govern.

Clarifications:

Closing date and time is February 3, 2014 at 1:00pm.  
Submit bid on SE-331 and acknowledge all addenda.  
Bids must be mailed or hand delivered to:  
Hatice Hikmet or Morris Nussbaum  
743 Greene St.  
Columbia, SC 29208

Questions/Answers

1. The specifications list the owner as purchasing 'all materials'; does this also include the pipe, valve and hangers or just the fixtures?

USC will furnish all materials. The low bidder will provide a material list of all piping, valves and hangers required. The fixtures are being provided by the millwork vender.

2. If the owner is purchasing the fixtures will they be receiving the O&M manuals and training from the vendors directly?

USC will receive the O&M manuals and be responsible for any training

3. The specifications state to ask about the use of facilities, will Port-a-Jon's be required.  
Facilities are provided on the floor.

4. Is the polypropylene 1/2 " lines used for the de-ionized water tubing or pipe?  
All concealed lines will be pipe.

Attachment: Sign in Sheet  
End of Addendum One