

**University of South Carolina
USC Baruch Marine Lab Mechanical HVAC Replacement
Project Number: CP00320788**

Addendum Number Three (3)

DATE: August 8, 2014

The following items add to, modify, clarify, or otherwise alter the Drawings and/or specifications and will become a part of the Contract Documents. Where a portion of the Drawings and/or specifications is added to, modified, clarified, or otherwise altered, the portion not so affected shall remain. Bidder shall include all effects that these items may have on his proposal.

Change

1. The closing date and time has been changed to Thursday - August 21, 2014 at 2PM at 743 Greene Street; Cola, SC; Conference Room 056.
2. **ALTERNATE NO 1.** Has been added to the project and must be quoted separately on the bid form **SE-331** on line **6.2**.

ALTERNATE NO. 1 INCLUDES THE FOLLOWING;

Substitute specified HVAC unit with a single zone package rooftop unit of similar and comparable construction to include curb as specified for the base bid unit. Alternate unit shall have the same nominal capacity and power requirements as the base bid unit. Alternate unit shall be equal to **JCI Model Series 10 J Single Zone Package Rooftop Unit with Electric Heat**. Substitutions are allowed, however the unit manufacturer must modify the unit to be supplied to provide 100% outside air.

END OF ADDENDUM Number Three (3)