



**WEST BOWL PORTAL ENTRIES
WILLIAMS BRICE STADIUM
UNIVERSITY OF SOUTH CAROLINA
CP00353757**

**Addendum One
August 6, 2012**

This addendum modifies the Contract Documents only in the manner and to the extent stated herein and shown on any accompanying drawings and will become a part of the Contract Documents. Except as specified or otherwise indicated by this addendum, all work shall be in accordance with the basic requirements of the Contract Documents.

GENERAL:

1. The Pre-Bid Meeting was held at the 743 Greene Street facility conference room on August 1, 2012 followed by a visit to the project site. The sign-in sheet of attendees is attached. The following items were discussed are hereby part of the contract documents:
 - a. It was determined and stated during this meeting that all questions must be submitted to the Architect by 12:00pm Friday 8/3 and the Addenda will be posted Monday 8/6 after 12:00pm.
 - b. Contractors call Duane Grooms for pre-bid access to the stadium. Phone: 803-777-8506.
 - c. The contractor is responsible for providing his own dumpster.

DRAWINGS:

1. Sheet D101: The aluminum bleacher section to be removed at each location is to be turned over to owner.
2. Sheet A301: Elevation "A" – Gate brackets shall be installed flush with the back side (short side) of wall to match adjacent gates. The gate brackets shall be installed 1" below the top of the short side of wall to match adjacent gates. Gates shall open freely 180 degrees. Gates shall have a 3/4" clearance between gate leaves. Gate latches indicated on drawings shall be Stanley slide pull polymer gate latches. The attachment of the steel plates shall be by three (3) 5/8" dia. all thread rods set 6" deep in the wall set in Hilti HY 150 epoxy adhesive in lieu of the bolts indicated on the drawings. Holes in walls are to be drilled 3/4" dia. or as indicated by Hilti written instructions. (Note: The above information supersedes that related information noted on the original Elevation "A" notes.)

END OF ADDENDUM

Jumper Carter Sease/Architects, P.A.
412 Meeting Street, West Columbia, South Carolina 29169
Phone 803.791.1020 Fax 803.791.1022



University of South Carolina
Williams-Brice Stadium West Side Portal Entries
Project Number: CP00353757
Non-Mandatory Pre-Bid Conference

August 1, 2012 @ 10:00 AM, 743 Greene Street, Columbia, SC 29208, Conf. Room 53

ATTENDEE'S NAME

COMPANY NAME & MAILING ADDRESS

TODD CANNON

Jumper Carter Souse Architects

PHONE# 791-1020

FAX# 791-1022

EMAIL TCannon@jcsarchitects.com

Raymond Hughes

Earthwise Construction Company

1306 Cedar Creek Road

SWANSEA, SC 29160

PHONE# 803-465-4887

FAX# —

EMAIL Raymond@EarthwiseConstructionCo.com

Steve Bross

First Class Construction, LLC

133 Vera Rd.

Lexington, S.C. 29012

PHONE# 803-926-1922

FAX# 803-926-1921

EMAIL sbross@fcon.com / tmeyer@fcon.com

Kay Keisler

USC

743 Greene Street

Columbia, SC 29208

PHONE# 803-777-5812

FAX# 803-777-8739

EMAIL KKeisler@fmc.sc.edu

Make sure to include your company name (on this form) as it is registered with LLR.
Please print clearly.



University of South Carolina
Williams-Brice Stadium West Side Portal Entries
Project Number: CP00353757
Non-Mandatory Pre-Bid Conference

August 1, 2012 @ 10:00 AM, 743 Greene Street, Columbia, SC 29208, Conf. Room 53

ATTENDEE'S NAME

COMPANY NAME & MAILING ADDRESS

Eddie Black

Strickland Waterproofing, LLC

PHONE# 704-347-1345

FAX# 704-347-1347

EMAIL EBlack@stricklandwaterproofing.com

WADE BOZEMAN

Pyramid Contracting

PHONE# 803-732-2050

FAX# 803-732-6881

EMAIL wade@pyramidcontracting.net

Brian Bolong

A+B Construction Group LLP

PHONE# 864-910-2775

FAX# 864-229-5383

EMAIL bb.const@live.com

Frank Ayers

Solid Structures

PHONE# 803-926-0298

FAX# 803-926-0299

EMAIL frayers@SolidStructures.info

**Make sure to include your company name (on this form) as it is registered with LLR.
Please print clearly.**



University of South Carolina
Williams-Brice Stadium West Side Portal Entries
Project Number: CP00353757

Non-Mandatory Pre-Bid Conference

August 1, 2012 @ 10:00 AM, 743 Greene Street, Columbia, SC 29208, Conf. Room 53

ATTENDEE'S NAME

COMPANY NAME & MAILING ADDRESS

Ben Lindler

Lindler Const.

PHONE# 803 252-9948

FAX# 796-6957

EMAIL HLST@BellSouth

JEFF DWIS

USC ATHLETICS

PHONE# 803-777-0459

FAX#

EMAIL jeffd@mailbox.sc.edu

Bob Kay

~~Bob Kay~~ Bullock Construction, LLC
Marty Bullock

PHONE# 513-6969

FAX#

EMAIL bbullock2@a.sc.rr.com

PHONE#

FAX#

EMAIL

Make sure to include your company name (on this form) as it is registered with LLR.
Please print clearly.