

Contract Documents and Specifications

For

Repair Work for Heyward Street Manhole

For

University of South Carolina

USC project # CP00377853

May 23, 2013

Design Team:

URS

TABLE OF CONTENTS

Project Number: CP00377853

Project Name: Repair Work for Heyward Street Manhole

Section 1	Number of Pages
Table of Contents	1
Invitation for Minor Construction Quotes (SE-311, 2011 Edition)	1
Standard Bid Quote (SE-331, 2011 Edition)	1
USC Supplemental General Conditions for Construction Projects	3
Contractor's One-Year Guarantee	1
Technical Specifications:	
02210 Site Grading	7
02221 Trenching/Backfilling for Utilities	6
02510 Stone Base Course	3
02513 Asphaltic Concrete Paving	3
02616 Milling, Cutting and Replacing Pavements	2
02721 Sewers: Storm Drainage	5

SE-311

Invitation for Minor Construction Quotes

SCBO NOTES 2, 4 and 5 APPLY TO THIS INVITATION FOR QUOTESPROJECT NAME: Repair Work for Heyward Street ManholePROJECT NUMBER: CP00377853 PROJECT LOCATION: USC Campus, Columbia, SCBID SECURITY REQUIRED? Yes ☐ No ☒PERFORMANCE BOND REQUIRED? Yes ☐ No ☒PAYMENT BOND REQUIRED? Yes ☐ No ☒ CONSTRUCTION COST RANGE: < \$ 50,000

DESCRIPTION OF PROJECT:

Excavation around Heyward Street Manhole and Vault and installation of stormwater drainage system.Small and minority business participation is encouraged.Contractors are responsible for obtaining bid documents and all updates from the USC purchasing websitehttp://purchasing.sc.edu See Facilities/Construction Solicitations and AwardsA/E NAME: URS Corporation A/E CONTACT: Chris SmithADDRESS: 101 Research Drive PHONE: 803-254-4400 Fax: 803-771-6676CITY: Columbia STATE: sc ZIP: 29202 E-MAIL: chris.c.smith@urs.com

PLANS ON FILE AT: AGC: _____

DODGE: _____

OTHER: _____

PLANS MAY BE OBTAINED FROM: http://purchasing.sc.edu See Facilities/Construction Solicitations and AwardsPLAN DEPOSIT AMOUNT: \$ 0 IS DEPOSIT REFUNDABLE? Yes ☐ No ☐PRE-QUOTE CONFERENCE? ☒ Yes ☐ No MANDATORY ATTENDANCE? ☐ Yes ☒ NoDATE: 6/3/13 TIME: 2:00pm PLACE: Facil Man Center, 743 Greene St, Cola, SC 29208, CR 53AGENCY: University of South CarolinaNAME AND TITLE OF AGENCY COORDINATOR: Michelle AdamsADDRESS: 743 Greene St PHONE: 803-777-0981 Fax: 803-777-0160CITY: Columbia STATE: SC ZIP: 29208 E-MAIL: mdadams@fmc.sc.eduIFQ CLOSING DATE: 6/10/13 TIME: 2:00pm LOCATION: 743 Greene St, Cola, SC 29208, CR53

IFQ DELIVERY ADDRESSES:

HAND-DELIVERY:

743 Greene St
Columbia, SC 29208
Attn: Michelle Adams

MAIL SERVICE:

743 Greene St
Columbia, SC 29208
Attn: Michelle AdamsIS PROJECT WITHIN AGENCY CONSTRUCTION CERTIFICATION? (Agency MUST check one) ☒ YES ☐ NO

APPROVED BY: _____

(State Engineer)

(Date)

SE-331

Quote Form

2011 Edition

Quotes shall be submitted only on SE-331

QUOTE SUBMITTED BY: _____
(Offeror's Name)

QUOTE SUBMITTED TO: University of South Carolina
(Agency Name)

FOR PROJECT: CP00377853 Repair Work for Heyward Street Manhole
(Number) (Name)

OFFER

1. In response to the Form SE-311, *Request for Minor Construction Quotes*, and in compliance with the *Instructions to Bidders* for the above-named Project, the undersigned **OFFEROR** proposes and agrees, if this Quote is accepted, to enter into a Contract with the **AGENCY** in the form included in the Solicitation Documents, and to perform all Work as specified or indicated in the Solicitation Documents, for the prices and within the time frames indicated in the Solicitation and in accordance with the other terms and conditions stated.

2. Pursuant to Section 11-32-3030(1) of the SC Code of Laws, as amended, **OFFEROR** has submitted Bid Security as follows in the amount and form required by the Solicitation Documents:

☐ Bid Bond with Power of Attorney ☐ Electronic Bid Bond ☐ Cashier's Check
(OFFEROR check one, if Bid Security is required)

3. **OFFEROR** acknowledges the receipt of the following Addenda to the Solicitation documents and has incorporated the effects of said Addenda into its Quote:

ADDENDUM No: _____

4. **OFFEROR** agrees that this Quote, including all bid alternates, if any, may not be revoked or withdrawn after the opening of bids, and shall remain open for acceptance for a period of 60 Days following the Quote Date, or for such longer period of time that **OFFEROR** may agree to in writing upon request of the **AGENCY**.

5. **OFFEROR** agrees that from the compensation to be paid, the **AGENCY** shall retain as Liquidated Damages the amount of for each calendar day the actual construction time required to achieve Substantial Completion exceeds the specified or adjusted Contract Time for Substantial Completion, as provided in the Contract Documents.

6. **OFFEROR** herewith submits its offer to provide all labor, materials, equipment, tools of trades and labor, accessories, appliances, warranties and guarantees, and to pay all royalties, fee, permits, licenses and applicable taxes necessary to complete the following items of construction work:

6.1 BASE BID _____
(enter BASE BID in figures only)

6.2 ALTERNATE NO. 1 _____ to be ADDED/DEDUCTED from BASE BID.
(circle one)

6.3 ALTERNATE NO. 2 _____ to be ADDED/DEDUCTED from BASE BID.
(circle one)

FEIN/SSN: _____

SC Contractor's
License Number: _____

Address: _____

Telephone/Fax _____

E-mail _____

This Quote is hereby submitted on behalf of the Offeror
named above.

BY: _____
(Signature of Offeror's Representative)

(Print or Type Name of Offeror's Representative)

ITS: _____

SE-331

USC SUPPLEMENTAL GENERAL CONDITIONS
FOR CONSTRUCTION PROJECTS

1. Contractor's employees shall take all reasonable means not to interrupt the flow of student traffic in building corridors, lobbies and stairs. All necessary and reasonable safety precautions shall be taken to prevent injury to building occupants while transporting materials and equipment through the building to the work area. Providing safe, accessible, plywood pedestrian ways around construction may be required if a suitable alternative route is not available.
2. Fraternalization between Contractor's employees and USC students, faculty or staff is strictly prohibited-zero tolerance!
3. USC will not tolerate rude, abusive or degrading behavior on the job site. Heckling and cat-calling directed toward students, faculty or staff or any other person on USC property is strictly prohibited. Any contractor whose employees violate this requirement will be assessed a fine of up to \$500 per violation.
4. Contractor's employees must adhere to the University's policy of maintaining a drug-free and smoke-free/tobacco free workplace.
5. Contractor must sign a Contractor Key Receipt/Return form before any keys are issued. Keys must be returned immediately upon the completion of the work. The Contractor will bear the cost of any re-keying necessary due to the loss of or failure to return keys.
6. A welding permit must be issued by the University Fire Marshall before any welding can begin inside a building. Project Manager will coordinate.
7. Contractor must notify the University immediately upon the discovery of suspect material such as those potentially containing asbestos or other such hazardous materials. These materials **must not** be disturbed until approved by the USC Project Manager.
8. At the beginning of the project, the USC Project Manager will establish the Contractor's lay-down area. This area will also be used for the Contractor's work vehicles. No personal vehicles will be allowed in this area, or in any areas surrounding the construction site that are not regular or authorized parking lots. Personal vehicles must be parked in the perimeter parking lots. Parking permits can be obtained at the USC Parking Office located in the Pendleton Street parking garage. The lay down area will be clearly identified to the contractor by the PM, with a sketch or drawing provided to Parking. In turn, the contractor will mark off this area with a sign containing the project name, PM name, Contractor name and contact number, and end date. Where this area is subject to foot traffic, protective barriers will be provided as specified by the PM. The area will be maintained in a neat and orderly fashion. Vehicles parked in the lay down area (or designated parking areas) will be clearly marked or display a CPC furnished placard for identification.

9. Contractor will be responsible for providing its own temporary toilet facilities, unless prior arrangements are made with the USC Project Manager.
10. Use of USC communications facilities (telephones, computers, etc.) by the Contractor is prohibited, unless prior arrangements are made with the USC Project Manager.
11. For all projects over \$100,000, including IDC's, an SE-395, Contractor Performance Evaluation, will be completed by the USC Project Manager and reviewed with the GC at the beginning of the project and a copy given to the GC. At the end of the project the form will be completed and a Construction Performance rating will be established.
12. Contractor is responsible for removal of all debris from the site, and is required to provide the necessary dumpsters which will be emptied at least 1 times per week. Construction waste must not be placed in University dumpsters. THE CONSTRUCTION SITE MUST BE THOROUGHLY CLEANED WITH ALL TRASH PICKED UP AND PROPERLY DISPOSED OF ON A DAILY BASIS AND THE SITE MUST BE LEFT IN A SAFE AND SANITARY CONDITION EACH DAY. THE UNIVERSITY WILL INSPECT JOB SITES REGULARLY AND WILL FINE ANY CONTRACTOR FOUND TO BE IN VIOLATION OF THIS REQUIREMENT AN AMOUNT OF UP TO \$1,000 PER VIOLATION.
13. **Contractor must provide all O&M manuals, as-built drawings, and training of USC personnel on new equipment, controls, etc. prior to Substantial Completion. Final payment will not be made until this is completed.**
14. The contractor will comply with all regulations set forth by OSHA and SCDHEC. Contractor must also adhere to USC's internal policies and procedures (available by request). As requested, the contractor will submit all Safety Programs and Certificates of Insurance to the University for review.
15. Tree protection fencing is required to protect existing trees and other landscape features to be preserved within a construction area. The limits of this fence will be evaluated for each situation with the consultant, USC Arborist and USC Project Manager. The tree protection fence shall be 5' high chain link fence unless otherwise approved by USC Project Manager. No entry or materials storage will be allowed inside the tree protection zone. A 4" layer of mulch shall be placed over the tree protection area to maintain moisture in the root zone.
16. Where it is necessary to cross walks, tree root zones (i.e., under canopy) or lawns the following measures shall be taken: For single loads up to 9,000 lbs., a 3/4" minimum plywood base shall be placed over areas impacted. For single loads over 9,000 lbs., two layers of 3/4" plywood is required.
17. For projects requiring heavy loads to cross walks tree root zones or lawns. A construction entry road consisting of 10' X 16' oak logging mats on 12" coarse, chipped, hardwood base. Mulch and logging mats shall be supplemented throughout the project to keep

matting structurally functional.

18. Any damage to existing landscaping (including lawn areas) will be remediated before final payment is made.
19. Orange safety fence to be provided by the contractor. (USC Arborist, Kevin Curtis may be contacted at 777-0033 or 315-0319)

Campus Vehicle Expectations

1. All motorized vehicles on the University campus are expected to travel and park on roadways and/or in parking stalls.
2. All motorized vehicle traffic on USC walkways must first receive the Landscape Manager=s authorization. Violators may be subject to fines and penalties.
3. All motorized vehicles that leak or drip liquids are prohibited from traveling or parking on walks or landscaped areas.
4. Contractors, vendors, and delivery personnel are required to obtain prior parking authorization before parking in a designated space. Violators may be subject to fines and/or penalties. See Item 10 below.
5. Drivers of equipment or motor vehicles that damage university hardscape or landscape will be held personally responsible for damages and restoration expense.
6. Vehicle drivers who park on landscape or drives must be able to produce written evidence of need or emergency requiring parking on same.
7. All vehicles parked on landscape, hardscape, or in the process of service delivery, must display adequate safety devices, i.e. flashing lights, cones, signage, etc.
8. All drivers of equipment and vehicles will be respectful of University landscape, equipment, structures, fixtures and signage.
9. All incidents of property damage will be reported to Parking Services or the Work Management Center.
10. Parking on campus is restricted to spaces designated by Parking Services at the beginning of the project. Once the project manager and contractor agree on how many spaces are needed, the project manager will obtain a placard for each vehicle. This placard must be hung from the mirror of the vehicle, otherwise a ticket will be issued and these tickets cannot be “fixed”. Parking spaces are restricted to work vehicles only; no personal vehicles.

Project Name: Repair Work for Heyward Street Manhole

Project Number: CP00377853

CONTRACTOR'S ONE YEAR GUARANTEE

STATE OF _____

COUNTY OF _____

WE _____
as General Contractor on the above-named project, do hereby guarantee that all work executed under the requirements of the Contract Documents shall be free from defects due to faulty materials and /or workmanship for a period of one (1) year from date of acceptance of the work by the Owner and/or Architect/Engineer; and hereby agree to remedy defects due to faulty materials and/or workmanship, and pay for any damage resulting wherefrom, at no cost to the Owner, provided; however, that the following are excluded from this guarantee;

Defects or failures resulting from abuse by Owner.

Damage caused by fire, tornado, hail, hurricane, acts of God, wars, riots, or civil commotion.

[Name of Contracting Firm]

*By _____

Title _____

*Must be executed by an office of the Contracting Firm.

SWORN TO before me this
_____ day of _____, 2____ (seal)

_____ State

My commission expires _____

SECTION 02210

SITE GRADING

PART 1 - GENERAL

1.1 DESCRIPTION

- A. Work included: Cut, fill, excavate, backfill, compact and grade the site as necessary to bring the roads, drives, building sites, paved areas and open areas to the lines and grades shown on the drawings.
1. The work includes, but is not necessarily limited to:
 - a. Roadway, parking area, drive and walk subgrade preparation.
- B. Related work:
1. Documents affecting work of this Section include, but are not necessarily limited to, General Conditions, Supplementary Conditions, and Sections in Division 1 of these specifications.
 2. Section 02221 - Trenching, Backfilling for Utilities.
 3. Section 02510 - Stone Base Course.
 4. Section 02721 - Sewers: Storm Drainage.
- C. Definitions:
1. Open areas: Open areas shall be those areas that do not include building sites, paved areas, street right-of-way and parking areas.
 2. Maximum density: Maximum weight in pounds per cubic foot of a specific material.
 3. Optimum moisture: Percentage of water in a specific material at maximum density.
 4. Rock excavation: Excavation of any hard natural substance which requires the use of explosives and/or special impact tools such as jack hammers, sledges, chisels or similar devices specifically designed for use in cutting or breaking rock, but exclusive of trench excavating machinery. To be considered as rock excavation, the material shall be continuous; individual boulders or rocks in soil will not be considered rock excavation.
 5. Muck: Materials unsuitable for foundation because of organic content, saturation to the extent that it is somewhat fluid and must be removed by dragline, dredge or other special equipment, are designated as muck. No extra payment will be made for muck removal.
 6. Unsuitable material: Unsuitable material is defined as earth material unsatisfactory for its intended use and as classified by the soils technician. In addition to organic matter, sod, muck, roots and rubbish, highly plastic clay soils of the CH and MH descriptions, and organic soils of the OL and OH descriptions, as defined in the Unified Soil Classification System shall be considered as unsuitable material.
 7. Suitable material: Where the term suitable material is used in specification sections pertaining to earthwork, it means earth or materials designated as being suitable for their intended use by soils technicians or the Engineer. Suitable material shall be designated as meeting the requirements of the Unified Soil Classification System types SW, GW, GC, SC, SM, ML, CL or as designated in these specifications.
 8. Select material: Select material is defined as granular material to be used where indicated on the drawings or where specified herein consisting of soils conforming to the Unified Soil Classification types SW, SM, GW or GM or as

- otherwise approved by the Engineer as select fill. Select material shall contain no stones or rubble larger than 1-1/2" in diameter.
9. Crushed stone (gravel): Crushed stone shall be No. 57 aggregate or equal conforming to ASTM C-33.
 10. Excavation: Excavation is defined as unclassified excavation of every description regardless of materials encountered.

- D. The Contractor must determine for himself the volume of material required by the site.

1.2 QUALITY ASSURANCE

- A. Use adequate numbers of skilled workmen who are thoroughly trained and experienced in the necessary crafts and who are completely familiar with the specified requirements and the methods needed for proper performance of the work of this Section.
- B. Comply with requirements of governmental agencies having jurisdiction.
- C. A testing laboratory retained by the Owner will make such tests as are deemed advisable. The Contractor shall schedule his work so as to permit a reasonable time for testing before placing succeeding lifts of fill material and shall keep the laboratory informed of his progress. The cost of the initial tests shall be paid for by the Owner. Subsequent tests required as a result of improper compaction shall be paid for by the Contractor.

1.4 JOB CONDITIONS

- B. Notification of intent to excavate:
 1. South Carolina Underground Utility Damage Prevention Act (S.C. Code Ann, 58-35-10, CT-SEQ, Supp. 1978) requires persons to ascertain the location of underground public utility property prior to excavation or demolition in certain situations. The Act also requires such persons to give timely notice of intent to excavate or demolish prior to commencing such operations. Failure to comply could subject the violator to a civil penalty of up to one thousand dollars (\$1,000) for each violation of the Act.
 2. Notification of intent to excavate may be given by calling this toll free number: 1-800-922-0983.

PART 2 - PRODUCTS

2.1 SOIL MATERIALS

- A. Soil material used as fill, backfill, subgrade for structures or pavements, embankments, or site grading shall consist of suitable material as found available on site until such supply of on-site material is depleted.
 1. Provide suitable material free from organic matter and deleterious substances, containing no rocks or lumps over 6" in greatest dimension, and with not more than 15% of the rocks or lumps larger than 2-1/2" in their greatest dimension.
 2. Do not permit rocks having a dimension greater than 1" in the upper 6" of fill or embankment.

- B. Should the quantity of suitable on-site material be insufficient to complete the work, suitable borrow material as approved by the Engineer shall be provided by the Contractor at no additional expense to the Owner.
- C. Select materials may be provided from on-site if acceptable material as approved by the Engineer is available on site. Otherwise approved select material shall be provided by the Contractor from an off-site source.

2.2 EQUIPMENT

- A. Use equipment adequate in size, capacity and numbers to accomplish the work in a timely manner without undue waste or damage of material.

PART 3 - EXECUTION

3.1 SURFACE CONDITIONS

- A. Examine the areas and conditions under which work of this Section will be performed. Correct conditions detrimental to timely and proper completion of the work. Do not proceed until unsatisfactory conditions are corrected.

3.2 PREPARATION

- A. Complete any demolition and/or removal work as may be required prior to grading operations.
- B. Sampling and preliminary testing:
 - 1. Prior to beginning the grading operations, the Contractor shall submit to the Engineer his proposed sequence of excavation operations.
 - 2. Based upon the sequence of excavation, samples of the fill materials will be obtained as excavation proceeds and tested for grain size permeability and moisture density relationship using the Standard Proctor Method (ASTM D698, Method A).
 - 3. Allow sufficient time for completion of laboratory tests before any fill operations begin, using the soils being tested.

3.3 FINISH ELEVATIONS AND LINES

- A. Construct areas outside of building or structure lines true to grades shown.
 - 1. Where no grade is indicated, shape finish surface to drain away from buildings or structures, as approved by the Engineer.
- B. Degree of finish shall be that ordinarily obtainable from blade grader, supplemented with hand raking and finishing.
- C. Finish surfaces to within 0.10' above or below the established grade or approved cross section.

3.4 GENERAL PROCEDURES

- A. Existing utilities:
 - 1. Unless shown to be removed, locate and protect active utility lines shown on the drawings or otherwise made known to the Contractor prior to excavating. If damaged, repair or replace at no additional cost to the Owner.

2. If active utility lines are encountered and are not shown on the drawings or otherwise made known to the Contractor, promptly notify the Engineer and take necessary steps to assure that service is not interrupted.
 3. If service is interrupted as a result of work under this Section, immediately restore service by repairing the damaged utility at no additional cost to the Owner.
 4. If existing utilities are found to interfere with the permanent facilities being constructed under this Section, immediately notify the Engineer and secure his instructions.
 5. Do not proceed with permanent relocation of utilities until written instructions are received from the Engineer.
- B. Protection of persons and property:
1. Barricade open holes and depressions occurring as part of this Work, and post warning lights on property adjacent to or with public access.
 2. Operate warning lights during hours from dusk to dawn each day and as otherwise required.
 3. Protect structures, utilities, sidewalks, pavements, and other facilities from damage caused by settlement, lateral movement, washout and other hazards created by operations under this Section.
- C. Use means necessary to prevent dust becoming a nuisance to the public, to neighbors, and to other work being performed on or near the site.
- D. Maintain access to adjacent areas at all times.
- E. Excavate and backfill in a manner and sequence that will provide proper drainage at all times.

3.5 EXCAVATING (CUTS)

- A. Perform excavating of every type of material encountered within the limits of the Work to the lines, grades and elevations indicated and specified herein.
- B. Suitable excavated materials:
1. Use all suitable materials removed from the excavation as far as practicable in the formation of the embankments, subgrades, shoulders, building sites and other places as directed.
 2. Unless otherwise indicated on the drawings or approved by the Engineer, surplus suitable material shall be removed from the site and disposed of by the Contractor.
- C. Unsuitable excavated material: Remove from the site and dispose of all unsuitable material unless otherwise approved by the Engineer.
- D. Rock excavation:
1. Notify the Engineer upon encountering rock or similar material which cannot be removed or excavated by conventional earth moving or ripping equipment.
 2. Do not use explosives without written permission from the Engineer.
 3. When explosives are permitted, use only experienced powdermen or persons who are licensed or otherwise authorized to use explosives. Store, handle and use explosives in strict accordance with all regulatory bodies and the "Manual of Accident Prevention in Construction" of the Associated General Contractors of America, Inc.

4. The Contractor shall be solely responsible for any damage resulting from the use of explosives.
 5. The Contractor is responsible for securing all permits required in performing this work.
- E. Unauthorized excavation:
1. Excavation of material to depths below the grades indicated unless so directed by the Engineer will be deemed unauthorized excavation.
 2. Unauthorized overexcavation shall be backfilled and compacted without any additional expense to the Owner.
- F. Authorized overexcavation:
1. In the event that it is necessary to remove unsuitable material to a depth greater than that shown on the drawings or otherwise specified, the Contractor, upon receiving direction from the Engineer, shall remove, replace and compact such material as directed by the Engineer at the unit prices indicated in the Bid Form.

3.6 FILLING AND BACKFILLING

- A. Use fills formed of suitable material placed in layers of not more than 8" in depth measured loose and rolled and/or vibrated with suitable equipment until compacted.
- B. Do not place rock that will not pass through a 6" diameter ring within the top 12" of the surface of the completed fill or rock that will not pass through a 3" diameter ring within the top 6" of the completed fill.
- C. Do not use broken concrete or asphaltic pavement in fills, unless it is crushed and graded to acceptable standards.
- D. Selection of borrow material:
1. Material in excess of that available on the site shall be suitable material furnished by the Contractor from private sources selected by the Contractor. The material shall be approved by the Engineer before use. All expenses involved in securing, developing, transporting and placing the material shall be borne by the Contractor.
- E. Placing and compacting:
1. Place backfill and fill materials in layers not more than 8" in loose depth.
 2. Before compacting, moisten or aerate each layer as necessary to provide the optimum moisture content.
 3. Compact each layer to required percentage of maximum density for the area.
 4. Do not place backfill or fill material on surfaces that are muddy, frozen, or contain frost or ice.
 5. Place backfill and fill materials evenly adjacent to structures, to required elevations.
 6. Take care to prevent wedging action of backfill against structures by carrying the material uniformly around the structures to approximately the same elevation in each lift.
- F. Moisture control:
1. Do not use soil material that is either too dry or too wet to achieve proper compaction.

2. Where subgrade or layer of soil material is too dry to achieve proper compaction, uniformly apply water to surface of soil material such that free water does not appear on the surface during or subsequent to compacting operations.
3. Remove and replace, or scarify and air dry, soil material that is too wet to permit compacting to the specified density.
4. Soil material that has been removed because it is too wet to permit compacting may be stockpiled or spread and allowed to dry. Assist drying by discing, harrowing, or pulverizing until moisture content is reduced to a satisfactory value as determined by moisture-density relation tests approved by the Engineer.

G. Compaction requirements:

1. Compact soils to not less than the following percentages of maximum dry density as determined in accordance with ASTM D698, Method A (Standard Proctor).
2. Fill beneath structures and beneath an area extending 10' beyond the limits of the foundation:

Top 12" of subgrade	100%
All other fill material	98%
(See Section 02220 for additional compaction requirements for fill beneath structures)	
3. Fill beneath roadway:

Top 12" of subgrade	100%
All other fill material	95%
4. Embankments:

Top 12" of subgrade	98%
All other fill material	95%
5. Fill beneath walkways:

Top 12" of subgrade	95%
All other fill material	90%
6. Lawn and unpaved open areas:

All other fill material	90%
-------------------------	-----

3.7 FINISH GRADING

A. General:

1. Uniformly grade the areas within limits of grading under this Section, including adjacent transition areas.
2. Smooth the finished surfaces within specified tolerance.
3. Grade with uniform levels or slopes between points where elevations are shown on the drawings, or between such points and existing grades.
4. Where a change of slope is indicated on the drawings, construct a rolled transition section having a minimum radius of approximately 8'0", unless adjacent construction will not permit such a transition, or if such a transition defeats positive control of drainage.

B. Grading adjacent to structures: Grade areas adjacent to buildings to achieve drainage away from the structures and to prevent ponding.

C. Ditches and gutters and swales:

1. Cut accurately to the cross sections, grades and elevations shown.
2. Maintain excavations free from detrimental quantities of leaves, sticks, trash and other debris until completion of the work.
3. Dispose of excavated materials as specified herein; do not in any case deposit materials within 3'0" of the edge of a ditch.

3.8 FIELD QUALITY CONTROL

- A. Secure the Engineer's construction review and observation and approval of subgrades and fill layers before subsequent construction is permitted thereon.
- B. Field density determinations will be made, at no cost to the Contractor, to ensure that the specified densities are being obtained except for fill under structures. Field density tests will be performed as determined by the Owner, considering the following:
 - 1. At areas to receive paving, at least one field density test for every 5,000 sq. ft. of subgrade area, but not less than three tests.
 - 2. In each compacted fill layer, one field density test for every 5,000 sq. ft. of overlying paved area, but not less than three tests.
 - 3. Other tests as deemed necessary by the Engineer or Owner.
- C. If, in the Engineer's opinion based on reports of the testing laboratory, subgrade or fills which have been placed are below specified density, provide additional compacting and testing until specified requirements are met.
 - 1. Additional testing will be provided by the Owner's selected testing laboratory and all costs for the additional testing will be borne by the Contractor.
- D. Proofrolling:
 - 1. The Contractor shall proofroll subgrade of areas to receive paving, structures on fill or impervious lining material.
 - a. Make not less than 3 passes of a 25 to 50 ton rubber tired roller over the full area.
 - b. Unstable, soft or otherwise unsuitable materials revealed by the proofrolling shall be removed and replaced with satisfactory materials, compacted as specified herein.

3.9 MEASUREMENT AND PAYMENT

- A. The work under this Section and all costs for same shall be included in the lump sum price bid for the item to which it pertains with additional or deductive payments allowed for the specified items based on the unit prices given in the Bid Form.
- B. Additive or deductive items:
 - 1. Rock excavation above or below that indicated on the drawings.
 - 2. Removal of additional unsuitable material.
 - 3. Backfill and compaction of suitable material to replace unsuitable material.

END OF SECTION

SECTION 02221

TRENCHING, BACKFILLING FOR UTILITIES

PART 1 - GENERAL

1.1 DESCRIPTION

- A. Work included: Trench, backfill, and compact as specified herein and as needed for installation of underground utilities associated with the Work.
- B. Related work:
 - 1. Documents affecting work of this Section include, but are not necessarily limited to, General Conditions, Supplementary Conditions and Sections in Division 1 of these Specifications.
 - 2. Section 02721 - Sewers: Storm Drainage.

1.2 QUALITY ASSURANCE

- A. Use adequate numbers of skilled workmen who are thoroughly trained and experienced in the necessary crafts and who are completely familiar with the specified requirements and the methods needed for proper performance of the work of this Section.
- B. Use equipment adequate in size, capacity, and numbers to accomplish the work in a timely manner.

1.3 JOB CONDITIONS

- A. Existing utilities:
 - 1. There now exists in the construction areas, waterworks, storm drainage, sanitary sewers, street paving, gas mains and other utilities.
 - 2. Approximate location of certain underground lines and structures are shown on the plans for information only, other underground lines or structures are not shown.
 - 3. Locate these and other possible unknown utility lines using electronic pipe finder, or other approved means.
 - 4. Locate, excavate and expose all existing underground lines in advance of trenching operations.
 - 5. The Contractor will be held responsible for the workmanlike repair of any damage done to any of these utilities in the execution of his work under this Section.
 - 6. The Contractor shall familiarize himself with the existing conditions and be prepared to adequately care for and safeguard himself and the Owner from damage.
- B. Notification of intent to excavate:
 - 1. South Carolina Underground Utility Damage Prevention Act (S.C. Code Ann, 58-35-10, CT-SEQ, Supp. 1978) requires persons to ascertain the location of underground public utility property prior to excavation or demolition in certain situations. The Act also requires such persons to give timely notice of intent to excavate or demolish prior to commencing such operations. Failure to comply could subject the violator to a civil penalty of up to one thousand dollars (\$1,000) for each violation of the Act.
 - 2. Notification of intent to excavate may be given by calling this toll free number: 1-888-721-7877.

PART 2 - PRODUCTS

2.1 EXCAVATED MATERIALS

- A. Perform all excavation of every description and of whatever substances encountered to depths indicated or specified.
- B. Pile material suitable for backfilling in an orderly manner at safe distance from banks or trenches to avoid overloading and to prevent slides or cave-ins.
- C. Remove and deposit unsuitable or excess materials as directed by the Owner.

2.2 BACKFILL MATERIALS

- A. Provide from materials excavated for installation of utility.
 - 1. Select soil material free from organic matter and deleterious substances, containing no rocks or lumps over 2" in greatest dimension for backfill up to 12" above top of utility being covered.
 - 2. Do not permit rocks larger than 2" in greatest dimension in top 6" of backfill.

2.3 OTHER MATERIALS

- A. Provide other materials, not specifically described but required for a complete and proper installation, as selected by the Contractor subject to the approval of the Owner.
- B. Should the quantity of suitable on-site material be insufficient to complete the work, provide suitable borrow material as approved by the Owner at no additional expense to the Owner.
- C. Provide select materials from on-site if acceptable material as approved by the Owner is available on-site. Otherwise, provide approved select material from an off-site source.

PART 3 - EXECUTION

3.1 PROCEDURES

- A. Existing utilities:
 - 1. Unless shown to be removed, protect active utility lines shown on the drawings or otherwise made known to the Contractor prior to trenching. If damaged, repair or replace at no additional cost to the Owner.
 - 2. If active utility lines are encountered and are not shown on the Drawings or otherwise made known to the Contractor, promptly take necessary steps to assure that service is not interrupted.
 - 3. If service is interrupted as a result of work under this Section, immediately restore service by repairing the damaged utility at no additional cost to the Owner.
 - 4. If existing utilities are found to interfere with the permanent facilities being constructed under this Section, immediately notify the Owner and secure his instructions.
 - 5. Do not proceed with permanent relocation of utilities until written instructions are received from the Owner.

- B. Locations within streets or highways:
1. Comply with South Carolina Department of Transportation's (SCDOT) "Encroachment Permit" issued for the Work, and the South Carolina Department of Transportation's (SCDOT) *"A Policy for Accommodating Utilities on Highway Rights-of-Way"*.
 2. Take all precautions and comply with all requirements as may be necessary to protect the improvements, including barricades for protection of traffic.
 3. Keep minimum of one lane open to traffic at all times where utility crosses street or highway.
- C. Protection of persons and property:
1. Barricade open holes and depressions occurring as part of the Work, and post warning lights on property adjacent to or with public access.
 2. Operate warning lights during hours from dusk to dawn each day and as otherwise required.
 3. Protect structures, utilities, sidewalks, pavements, and other facilities from damage caused by settlement, lateral movement, washout and other hazards created by operations under this Section.
- D. Dewatering:
1. Remove all surface and subsurface waters from excavations and maintain the excavation in a dry condition during construction operations.
 2. Maintain the ground water level a minimum of 3-feet below the trench bottom during excavation, installation and backfilling.
 - a. Material disturbed below the invert elevation due to improper dewatering shall be removed and replaced with crushed stone or lean concrete at no expense to the Owner.
 - b. Use sumps, pumps, drains, trenching, wells, vacuum or well point system as necessary to maintain the ground water level a minimum of 3-feet below the trench bottom and maintain a dry excavation.
 - c. Dewatering by trench pumping will not be permitted if migration of fine grained natural material (running sand) from bottom, side walls or bedding material will occur.
 - d. Provide monitoring wells sufficient in size, location, number and depth to monitor the ground water level in the construction area during excavation and backfill operations.
 - e. Maintain dewatering operations until backfilling and compaction operations are complete.
 3. Dispose of water pumped from excavations in storm drains having capacity, canals, trenches or other approved locations.
 - a. Contractor is responsible for acquiring all permits required to discharge the water and shall protect waterways from turbidity during the operation.
 - b. Prevent flooding of streets, roadways, or private property.
 - c. Provide engines driving dewatering pumps with residential type mufflers.
- E. Use means necessary to prevent dust becoming a nuisance to the public, to neighbors, and to other work being performed on or near the site.
- F. Maintain access to adjacent areas at all times.

3.2 TRENCH EXCAVATION (Classified)

- A. Remove all materials of whatever substance encountered, additional payment to be made for rock excavation as hereinafter defined and specified.
 - 1. Rock excavation to consist of the removal and disposal of the following materials:
 - a. Boulders 1/2 cubic yard or more in volume.
 - b. Solid rock.
 - c. Materials that cannot be excavated with a backhoe having a minimum bucket curling force of not less than 30,000 pounds and outfitted with a rock bucket with pointed hardened rock teeth.
 - d. Concrete and masonry structures exceeding 1/2 cubic yard in volume except sidewalks and paving.
 - 2. Rock excavation does not include:
 - a. Boulders, concrete or masonry structures less than 1/2 cubic yard in volume.
 - b. Hard and compact materials such as cemented gravel and relatively soft or disintegrated rock that can be removed without continuous and systematic drilling and blasting.
 - c. Material removed by intermittent drilling and blasting performed to increase production.
 - 3. Do not remove material claimed as rock until the Engineer has classified and cross-sectioned same.
- B. Where trenching occurs in existing lawns, remove turf in sections and keep damp. Replace turf upon completion of the backfilling.
- C. Open cut:
 - 1. Excavate for utilities by open cut.
 - 2. If conditions at the site prevent such open cut, and if approved by the Owner, tunneling may be used.
 - 3. Short sections of a trench may be tunneled if, in the opinion of the Owner, the conductor can be installed safely and backfill can be compacted properly into such tunnel.
 - 4. Remove boulders and other interfering objects, and backfill voids left by such removals, at no additional cost to the Owner.
 - 5. Remove wet or otherwise unstable soil incapable of properly supporting the utility, as determined by the Owner, to depth required and backfill to proper grade with stone bedding material, at no additional cost to the Owner.
 - 6. Excavating for appurtenances:
 - a. Excavate for manholes and similar structures to a distance sufficient to leave at least 12" clear between outer surfaces and the embankment or shoring that may be used to hold and protect the banks.
 - b. Overdepth excavation beyond such appurtenances that has not been directed will be considered unauthorized. Fill with sand, gravel, or lean concrete as directed by the Owner, and at no additional cost to the Owner.
- D. Trench to the minimum width necessary for proper installation of the utility, with sides as nearly vertical as possible. Accurately grade the bottom to provide uniform bearing for the utility.
- E. Provide sheeting and shoring necessary for protection of the Work and for the safety of personnel.

1. Remove in units when level of backfilling has reached the elevation necessary to protect the utility work and adjacent property.

F. Depressions:

1. Dig bell holes and depressions for joints after the trench has been graded. Provide uniform bearing for the pipe on prepared bottom of the trench.
2. Except where rock is encountered, do not excavate below the depth indicated or specified.
3. Where rock is encountered, excavate rock to a minimum overdepth of 4" below the trench depth indicated or specified, and to provide 6" clearance in any horizontal direction from all parts of the utility and appurtenances.

G. Special requirements relating to excavation for specific types of utilities shall comply with the following:

1. Sanitary or storm sewer lines:
 - a. Comply with requirements of Section 02721.
 - b. Do not excavate trench more than 200' ahead of pipe laying, unless permitted by Engineer.
 - c. Maintain trench sides vertical to point not less than 2' above top of pipe.
 - d. Upper portion of trench may be sloped to any width which will not cause damage to adjoining structures, utilities, pavements or private property.

H. Comply with pertinent OSHA regulations in regards to the excavation of utilities.

3.3 BACKFILLING

A. General:

1. Backfill trenches and excavations immediately after the pipes are laid, unless other protection is directed or indicated.
2. Select and deposit backfill materials with special reference to the future safety of the pipes.
3. Reopen trenches which have been improperly backfilled, to a depth as required for proper compaction. Refill and compact as specified, or otherwise correct to the approval of the Owner.
4. Surplus material shall be disposed of as directed by the Owner.
5. Original surface shall be restored to the approval of the Owner.
6. Maintain proper dewatering during backfill and compaction operations.

B. Lower portion of trench:

1. Deposit approved backfill and bedding material in layers of 6" maximum thickness, and compact with suitable tampers to the density of the adjacent soil until there is a cover of not less than 24" over sewers and 12" over other utility lines.
2. Take special care in backfilling and bedding operations not to damage pipe and pipe coatings.

C. Remainder of trench:

1. Except for special materials for pavements, backfill the remainder of the trench with material free from stones larger than 6" or 1/2 the layered thickness, whichever is smaller, in any dimension.
2. Deposit backfill material in layers not exceeding the thickness specified, and compact each layer to the minimum density directed by the soil engineer.

D. Under roads, streets and other paved areas:

1. Mechanically tamp in 6" layers using heavy duty pneumatic tampers or equal.
2. Compact to densities outlined in Section 02210..
3. Provide additional compaction by leaving the backfilled trench open to traffic while maintaining the surface with crushed stone.
4. Refill any settlement with crushed stone and continue such maintenance until replacement of pavement is authorized by the Engineer.

3.4 MEASUREMENT AND PAYMENT

A. Unclassified excavation:

1. No measurement or direct payment will be made for the Work under this Section and all costs for same shall be included in the lump sum price bid for the project.

END OF SECTION

SECTION 02510
STONE BASE COURSE

PART 1 - GENERAL

1.1 DESCRIPTION

- A. Work included: Provide crushed stone base (with prime) constructed on the compacted subgrade where shown on the Drawings, as specified herein, and as needed for a complete and proper installation.
- B. Related work:
 - 1. Documents affecting work of this Section include, but are not necessarily limited to, General Conditions, Supplementary Conditions, and Sections in Division 1 of these Specifications.
 - 2. Section 02210 - Site Grading.
 - 3. Section 02513 - Asphaltic Concrete Paving.

1.2 QUALITY ASSURANCE

- A. Use adequate numbers of skilled workmen who are thoroughly trained and experienced in the necessary crafts and who are completely familiar with the specified requirements and the methods needed for proper performance of the work of this Section.

1.3 SUBMITTALS

- A. Submit shop drawings to Engineer for review/approval.
- B. Certificates, signed by materials producer, stating that materials meet the specified requirements.

PART 2 - PRODUCTS

2.1 COARSE AGGREGATE

- A. Furnish a coarse aggregate (retained on No. 4 sieve) consisting of hard, durable particles of stone, reasonably free from soft, thin, elongated or laminated pieces and deleterious substances.
- B. Furnish aggregate with an abrasion loss of less than 65% as measured by the Los Angeles Abrasion Test.

2.2 FINE AGGREGATE

- A. Furnish a fine aggregate consisting of material produced by stone crushing operations.
- B. Liquid limit shall not exceed 25 and the plasticity index shall not exceed 6 when tested in accordance with AASHTO T-89 and T-90, respectively.

2.3 COMPOSITE MIXTURE

- A. Produce in one crushing operation or by blending the fine and coarse aggregate in proper proportions.

- B. After the materials have been mixed, laid down, and initial compaction operations begun, the composite mixture shall conform to the following:

Sieve Designation	Percent by Weight Passing
2"	100
1-1/2"	95-100
1"	70-100
1/2"	48-75
No. 4	30-50
No. 30	11-30
No. 200	0-12
Liquid Limit	25 max.
Plasticity Index	6 max.

2.4 PRIME ASPHALT

- A. Use either MC-30, RC-30, RC-70, or EA-P complying with requirements of Sections 406, 407 and 408 of the South Carolina Department of Transportation specifications.

PART 3 - EXECUTION

3.1 PREPARATION OF SUBGRADE

- A. Proofroll all areas to receive crushed stone paving.
1. Make not less than three passes over the full area, using a 35 to 50 ton rubber tired roller.
- B. Remove all soft, unstable or unsuitable material that will not compact readily.
1. Remove to full depth of unsuitable material, or to a depth of 30", whichever is less.
 2. Replace with satisfactory materials.
- C. Fill all holes, ruts or depressions which develop in the subgrade with approved on-site material, bringing subgrade to indicated line and grades.
- D. Compact subgrade using suitable construction procedures to provide not less than 95% Standard Proctor Maximum Dry Density.
- E. Seal roll the subgrade surface with a steel wheel roller, sealing the surface against excessive water infiltration.

3.2 PLACING AND MIXING OF PAVING MATERIAL

- A. Place aggregates using spreader boxes or other approved spreaders uniformly on one operation.
- B. Take care to avoid segregation of the fine from the coarse aggregate during handling, spreading or shaping operations.
- C. Mix, while at proper moisture, with motor grader or other equipment and maintain to required section and grade until thoroughly compacted.

3.3 ROLLING AND COMPACTING

- A. Perform using 3-wheel steel wheel roller weighing not less than 10 tons, tandem roller weighing at least 8 tons, or other rollers approved by the Engineer.
- B. Start rolling at edges and proceed toward the center, continue rolling until aggregates are firmly keyed or set.
- C. When initial compaction is completed, should voids remain, place fine aggregates on the surface in an amount only sufficient to fill the voids.
- D. Broom, wet and roll until coarse aggregate is set, bonded and thoroughly compacted for full width and depth.

3.4 ALLOWABLE TOLERANCES

- A. Thickness tolerance: Provide the compacted thicknesses shown on the Drawings within a tolerance of minus 1/2".
 - 1. Depth measurements will be made by digging through the base at intervals no closer than 250', nor greater than 500' apart.
 - 2. Where thickness is less than depth specified minus 1/2", it shall be corrected as directed by the Engineer.
- B. Smoothness tolerance: Provide the lines and grades shown on the Drawings within a tolerance of 3/8" in 10', parallel to the center line of the roadway nor more than 1/2" from a template conforming to the cross sections shown on the plans.
- C. Deviations: Correct by removing materials, replacing with new materials, and reworking or recompacting as required.

3.5 PLACING PRIME COAT

- A. Allow base course to season sufficiently to permit uniform penetration.
- B. Do not apply to wet surfaces or when the temperature is below 60°F in the shade and falling, or below 55°F in the shade and rising.
- C. Clean surfaces of all dust, dirt, clay, etc. using mechanical brooms, etc.
- D. Apply prime material, using pneumatic mounted distributors, at a rate of 0.25 to 0.30 gallon per square yard.
- E. Permit no traffic on primed surfaces until bituminous material has penetrated and dried sufficiently that it does not pick up under traffic.

3.6 MEASUREMENT AND PAYMENT

- A. No separate measurement or direct payment will be made for this work and all costs for same shall be included in the lump sum price bid for the project.

END OF SECTION

SECTION 02513
ASPHALTIC CONCRETE PAVING

PART 1 - GENERAL

1.1 DESCRIPTION

- A. Work included: Provide asphaltic concrete paving where shown on the Drawings, as specified herein, and as needed for a complete and proper installation.
- B. Related work:
 - 1. Documents affecting work of this Section include, but are not necessarily limited to, General Conditions, Supplementary Conditions, and Sections in Division 1 of these Specifications.
 - 2. Section 02210 - Site Grading.
 - 3. Section 02510 - Stone Base Course.

1.2 QUALITY ASSURANCE

- A. Use adequate numbers of skilled workmen who are thoroughly trained and experienced in the necessary crafts and who are completely familiar with the specified requirements and the methods needed for proper performance of the work of this Section.

1.3 SUBMITTALS

- A. Submit shop drawings to Engineer for review/approval.
- B. Product data: Within thirty five (35) calendar days after the Contractor has received the Owner's Notice to Proceed, submit:
 - 1. Materials list of items proposed to be provided under this Section.
 - 2. Certificates, signed by the materials producer and the asphalt paving Subcontractor, stating that materials meet or exceed the specified requirements.

PART 2 - PRODUCTS

2.1 GENERAL

- A. All materials and products used shall comply with pertinent sections of the South Carolina Department of Transportation's (SCDOT) "Standard Specifications for Highway Construction".

2.2 ASPHALTIC CONCRETE MIXTURE (BINDER COURSE)

- A. Materials and composition of mixture shall comply with Section 402 of the SCDOT's "Standard Specifications for Type 1 Mix".
- B. Provide hot plant mixed asphaltic concrete paving materials.
 - 1. Temperature leaving the plant: 290°F minimum, 320°F maximum.
 - 2. Temperature at time of placing: 280°F minimum.

2.3 ASPHALTIC CONCRETE MIXTURE (SURFACE COURSE)

- A. Materials and composition of mixture shall comply with Section 403 of the SCDOT's "Standard Specifications for Type 1 Mix."
- B. Provide hot plant mixed asphaltic concrete paving materials.
 - 1. Temperature leaving the plant: 290°F minimum, 320°F maximum.
 - 2. Temperature at time of placing: 280°F minimum.

2.4 EQUIPMENT

- A. Comply with requirements of Section 401 of SCDOT's "Standard Specifications".

PART 3 - EXECUTION

3.1 SURFACE CONDITIONS

- A. Examine the areas and conditions under which work of this Section will be performed. Correct conditions detrimental to timely and proper completion of the Work. Do not proceed until unsatisfactory conditions are corrected.
 - 1. Sweep primed surfaces if needed.
 - 2. Adjust frames and covers if needed.

3.2 WEATHER RESTRICTIONS

- A. Do not apply asphalt mixtures to a wet or frozen surface or when air temperature is below 40°F in the shade and falling, or below 35°F in the shade and rising.

3.3 SPREADING AND FINISHING

- A. On arrival at point of use, dump directly into mechanical spreader.
- B. Immediately spread and strike off true to the line, grade and cross section indicated, to such loose depth that when work is completed, the indicated thickness or weight per square yard will be secured.
- C. Correct irregularities while the mixture is still hot.
- D. At locations not readily accessible to mechanical spreaders, acceptable hand spreading methods may be used.
- E. Finished surfaces placed adjacent to curbs, gutters, manholes, etc., shall be approximately 1/4" above the edges of these structures.

3.4 COMPACTION

- A. Perform initial rolling with 3-wheel steel roller or a steel wheel 2-axle tandem roller.
- B. Follow initial rolling with at least four complete coverages by a pneumatic tired roller.
- C. Complete rolling with steel wheel 2-axle tandem roller.
- D. Rolling shall start longitudinally at the sides and proceed gradually toward the center of the pavement, overlapping on successive trips approximately 1/2 the width of the roller.
- E. Use hand or mechanical tampers in areas not accessible to powered rollers.

- F. Surface mixture after compaction shall be smooth and true to the established crown and grade.
 - G. Finished paving smoothness tolerance:
 - 1. Free from birdbaths.
 - 2. No deviations greater than 1/8" in 6'.
- 3.5 PROTECTION OF SURFACE
- A. Allow no traffic on surface until the mixture has hardened sufficiently to prevent distortion.
- 3.6 FLOOD TEST
- A. Flood the entire asphaltic concrete paved area with water by use of a tank truck or hoses.
 - B. If a depression is found where water ponds to a depth of more than 1/8" in 6', fill or otherwise correct to provide proper drainage.
 - C. Feather and smooth the edges of fill so that the joint between fill and original surface is invisible.
- 3.7 MEASUREMENT AND PAYMENT
- A. No separate measurement or direct payment will be made for this work and all costs for same shall be included in the lump sum price bid for the project.

END OF SECTION

SECTION 02616
MILLING, CUTTING AND REPLACING PAVEMENTS

PART 1 - GENERAL

1.1 DESCRIPTION

- A. Work included: Milling, cutting and replacement of existing pavements for installation of storm drainage lines, as specified herein, and as needed for a complete and proper installation of transitions to existing pavement at project boundaries.
- B. Related work:
 - 1. Documents affecting work of this Section include, but are not necessarily limited to, General Conditions, Supplementary Conditions, and Sections in Division 1 of these specifications.
 - 2. Section 02210 – Site Grading.
 - 3. Section 02221 - Trenching, Backfilling for Utilities.
 - 4. Section 02510 – Stone Base Course.
 - 5. Section 02513 - Asphaltic Concrete Paving.
 - 6. Section 02721 - Sewers: Storm Drainage.

1.2 QUALITY ASSURANCE

- A. Use adequate numbers of skilled workmen who are thoroughly trained and experienced in the necessary crafts and who are completely familiar with the specified requirements and the methods for proper performance of the work of this Section.

1.3 SUBMITTALS

- A. Submit shop drawings to Engineer for review/approval.

1.4 WARRANTY

- A. All remove and replace pavement work within the South Carolina Department of Transportation (SCDOT) rights-of-way shall be warranted for two years beginning on the date of acceptance by the SCDOT.

PART 2 - PRODUCTS

2.1 ASPHALTIC CONCRETE

- A. Comply with Section 02513.

2.2 AGGREGATE BASE COURSE WITH PRIME

- A. Comply with Sections 02510 and 02513.

PART 3 - EXECUTION

3.1 GENERAL

- A. Remove to neat lines and dispose of as directed.
- B. Replace with bases and pavements as required by Sections 02510 and 02513 and the Construction Plans.

3.2 CUTTING

- A. Asphalt pavement or base:
 - 1. Cut on straight and true lines, to a minimum depth of 2", using powered concrete saw.
 - 2. Shear off remaining depth with pneumatic tools.
- B. Concrete sidewalks shall be removed back to the nearest joint on each side of the crossing.
- C. Cut to straight and true lines with powered concrete saw.

3.3 MILLING

- A. Use self-propelled milling equipment capable of maintaining accurate cut depth and slope and providing smooth cut edges.
- B. Ensure the equipment can accurately and adequately establish profile grade and control cross slope.
- C. Equip the milling machine with integral material pickup and truck discharges.
- D. Ensure the milling machine has effective means for dust control.
- E. Material size to comply with SCDOT specifications.

3.4 REPLACEMENT

- A. Flexible pavements:
 - 1. Compact subgrade according to Section 02210 - Site Grading.
 - 2. Undercut each edge 6" to form a shelf.
 - 3. Replace with bases and pavements as required by Sections 02510 and 02513 and the Construction Plans.

3.5 MEASUREMENT AND PAYMENT

- A. No measurement or direct payment will be made for the work under this Section and all costs for same shall be included in the price bid for the project.

END OF SECTION

SECTION 02721
SEWERS: STORM DRAINAGE

PART 1 - GENERAL

1.1 DESCRIPTION

- A. Work included: Provide storm drainage sewer as shown on the drawings, specified herein, and needed for a complete and proper installation.
- B. Related work:
 - 1. Documents affecting work of this Section include, but are not necessarily limited to, General Conditions, Supplementary Conditions, and Sections in Division 1 of these specifications.

1.2 QUALITY ASSURANCE

- A. Use adequate numbers of skilled workmen who are thoroughly trained and experienced in the necessary crafts and who are completely familiar with the specified requirements and the methods needed for proper performance of the work of this Section.
- B. All materials in this Section are to be manufactured in the United States.
- C. Contractor to be certified by the manufacturer for installation of HDPE pipe.

1.3 SUBMITTALS

- A. Submit shop drawings to Engineer for review/approval.
- B. Product data: Within fifteen (15) calendar days after the Contractor has received the Owner's Notice to Proceed, submit:
 - 1. Materials list of items proposed to be provided under this Section.
 - 2. Manufacturer's specifications and other data needed to prove compliance with the specified requirements.

1.4 ORDER AND ACCEPTANCE OF WORK

- A. Engineer shall direct on what line or street the Contractor shall work and the order thereof.
 - 1. Generally, work shall commence at the lower end of a system and proceed upgrade.

1.5 PROTECTION OF OTHER UTILITIES

- A. Location:
 - 1. Approximate location of certain known underground lines is shown.
 - 2. Existing small lines not shown.
 - 3. Locate small and other possible utility lines using electronic pipe finder, or other approved method.
 - 4. Excavate and expose existing underground utilities ahead of trenching operations.

- B. Repair or replace any damaged utility line or structure at no additional cost to Owner.

1.6 CONFLICTING UTILITIES

- A. Remove and/or relay conflicting utilities, when so directed by the Engineer, at the expense of the Owner.
- B. Where alterations to existing utilities are shown to avoid conflicts, make alterations at no cost to Owner.

PART 2 - PRODUCTS

2.1 GENERAL

- A. Pipe shall be subject to Engineer's observation, at plant, trench or other point of delivery, for culling and rejecting pipe, independent of laboratory tests, not conforming to specifications.
- B. Rejected pipe will be marked by the Engineer and Contractor shall remove it from project site.

2.2 PIPE AND MATERIALS

- A. High density polyethylene pipe (HDPE):
 - 1. Manufacture from High Density Polyethylene (HDPE) virgin compounds conforming to cell classifications as listed in AASHTO M-252 and M-294, Type S, MP7-97 (Type D and DP).
 - 2. Form with annular corrugation, conforming to AASHTO M-294.
 - a. Furnish a Certificate of Compliance to the Engineer for each type of plastic pipe furnished.
 - b. Provide integrated bell and spigot joints with ASTM F-477 rubber gasket on spigot end.

2.3 OTHER MATERIALS

- A. Provide other materials, not specifically described but required for a complete and proper installation, as selected by the Contractor subject to the approval of the Engineer.

PART 3 - EXECUTION

3.1 LAYING OUT WORK

- A. Provide all materials, labor, instruments, etc. required to lay out Work.
- B. Prepare "cut sheets" under direct supervision of the Engineer.
- C. Exercise proper precaution to verify figures on the drawings prior to laying out Work. Contractor will be held responsible for any errors therein that otherwise might have been avoided.
- D. Promptly inform Engineer of errors or discrepancies found, in order that proper corrections may be made.

3.2 INSTALLATION

A. Trench, backfill and compact for the work of this Section in strict accordance with pertinent provisions of Section 02221 and Section 02616 of these specifications, and the following requirements:

1. Maximum trench widths, depths and bedding methods.
 - a. Install all sewers complying with tables for depths of cut and class of bedding included hereinafter.
 - b. Where trenches are excavated beyond specified widths, or trench walls collapse, lay sewer complying with requirements of the next better class of bedding at no additional cost to the Owner.
 - c. Include cost of special bedding and tamping in unit prices bid for sewer.
2. High density polyethylene pipe (HDPE) to be installed per ASTM D2321 and AASHTO Section 30 requirements.
3. High density polyethylene pipe (HDPE):

MAXIMUM DEPTHS IN FEET					
CLASS OF BEDDING					
Pipe Size	Min. Trench Width	D	C	B	A
		Flat Bottom Trench	Type 1 or Type 2	Type 1 or Type 2* Bedding	Special Concrete Bedding
4"	2'0"	**	**	30	**
6"	2'2"	**	**	30	**
8"	2'4"	**	**	30	**
10"	2'6"	**	**	30	**
12"	3'0"	**	**	30	**
15"	3'3"	**	**	30	**
18"	3'6"	**	**	30	**
24"	4'0"	**	**	30	**
30"	5'6"	**	**	30	**
36"	6'6"	**	**	30	**
42"	7'0"	**	**	30	**
48"	7'8"	**	**	30	**

* Class B Bedding (Type 2) shall extend to the top of the pipe.

** Do not use this Class of bedding for this pipe size and trench width.

B. Bedding and tamping requirements for the various classes of bedding shall comply with the following specifications:

1. Class A Bedding - Excavate trench to one-fourth of nominal pipe diameter below pipe grade; lay pipe to grade on concrete blocking; place 2500 psi concrete around pipe for full width of trench up to one-fourth nominal pipe diameter above the invert.
2. Class B (Type 1) Bedding - Shape bottom of trench to a level two inches below bottom of pipe; bring bed to proper level by spreading and thoroughly tamping fine granulated moist earth and sand to conform accurately to one-fourth circumference of pipe barrel; provide suitable material if not available from trench excavation; lay pipe, backfill and hand tamp in thin layers to height three-fourths of pipe diameter, using material same as bedding material; complete trench backfill complying with Section 02221.

- a. Bring trenches excavated to excess depths to grade with stone or gravel bedding at the Contractor's expense.
- b. Exercise care to avoid disturbing pipe grade, alignment or joints at all times.
- c. In lieu of this class bedding, Contractor may elect to use Class B (Type 2) bedding.
- 3. Class B (Type 2) Bedding - Undercut 4" below pipe barrel, full width of trench; bring to grade with crushed stone complying with SCDOT Aggregate No. 5; except for HDPE, use SCDOT Aggregate No. 57.
 - a. For HDPE pipe, place stone (Aggregate No. 57) in 6" layers to the top of the pipe, compacting by slicing with shovel.
 - b. Complete trench backfill complying with Section 02221.
- 4. Class C (Type 1) bedding - Shape trench bottom by hand to conform accurately to bottom one-quarter of pipe barrel circumference.
 - a. Use Class C (Type 2) bedding if unable to properly shape trench bottom.
 - b. If shaping is not performed accurately, the Contractor will be required to use Class C (Type 2) bedding.
- 5. Class C (Type 2) Bedding - Undercut 4" below bottom of pipe barrel; full width of trench; bring to grade with compacted crushed stone complying with SCDOT Aggregate No. 5; lay pipe; place stone in six-inch layers to quarter-point of pipe, compacting by slicing with shovel; complete backfill complying with Section 02221.

C. Pipe laying:

- 1. General:
 - a. Protect pipe during handling against shocks and free fall. Remove extraneous material from the pipe interior.
 - b. Lay pipe by proceeding upgrade with the spigot ends of bell-and-spigot pipe pointing in direction of flow.
 - c. Lay each pipe accurately to the indicated line and grade, aligning so the sewer has a uniform invert.
 - d. Continually clear interior of the pipe free from foreign material.
 - e. Before making pipe joints, clean and dry all surfaces of the pipe to be joined.
 - f. Use gasket lubricants or joint primers as recommended by the pipe manufacturer.
 - g. Place, fit, join and adjust the joints to obtain the degree of water tightness required.
- 2. High density polyethylene pipe (HDPE):
 - a. Provide proper equipment for hoisting and lowering pipe into the trench without damaging the pipe or disturbing the bedding and the sides of the trench.
 - b. Remove shipping collars prior to placing pipe in trench.
 - c. Lay pipe with the green stripe up.
 - d. Align the joint and push the spigot home.
 - e. Use a bar and wood block on larger diameters when necessary making sure the block protects the pipe end from the bar.
 - f. When pushing the joint home, make sure the bedding material is not pulled into the bell by the spigot.
 - g. Take up and re-lay any pipe which is not in alignment or which shows any undue settlement after laying, without additional compensation.

3.3 OBSERVATIONS

A. General:

1. Clean and prepare for observation each block or section of sewer upon completion, or at such other time as the Engineer may direct.
2. Each section between manholes shall show a full circle of light when viewed from either end.
3. Repair all visible leaks.
4. Correct broken or cracked pipe, mislaid pipe and other defects.
5. All repairs, relaying of sewers, etc. required to bring the sewers to specified status shall be made at no additional cost to the Owner.

3.6 MEASUREMENT AND PAYMENT

- #### A.
- No separate measurement or direct payment will be made for the items under this Section and all costs for same shall be included in the lump sum price bid for the project.

END OF SECTION