

Mechanical Addendum Three

April 22, 2015

NOTE: The following amendments, additions, and deletions shall be made to the Construction Documents and Contract Documents. Insofar as those documents are at variance with this Addendum, this Addendum shall govern.

Specifications

Item No.      Description

1.                Revision: Reference Invitation for Construction Services SE-310: Change the Bid Closing Date to April 28, 2015 at 2:30 PM.

Specifications

Item No.      Description

2.                Revision: Reference Section 15010 General Provisions – Mechanical. Reference Part 1 – General, Manufacturers: The following shall be included as a prior approved manufacturer.

Expansion Joints: Bellows Manufacturing and Research

3.                Revision: Reference Section 15650 HVAC Piping. Reference Part 2 – Products, Expansion Joints. Change the model number of the expansion joints to FP-D/300, the joints shall be able to accept expansion in two directions. The expansion joints shall accommodate up to 8” axial movement for pipe expansion in each direction, for a total of 16” total expansion. End fittings shall be carbon steel standard wall beveled weld ends for weld end models.

END OF ADDENDUM