

## **ADDENDUM NO. 02**

The following items shall take precedence over the drawings and specifications for the above named project and shall become a part of the contract documents. Where any item called for in the specifications, or indicated on the drawings, is not supplemented hereby, the original requirements shall remain in effect. Where any original item is amended, voided, or superseded hereby, the provisions of such item not specifically amended, voided or superseded shall remain in effect.

Acknowledge receipt of this Addendum in the appropriate space on the Bid Form. Failure to do so may subject the bidder to disqualification.

### **Attachments**

Documents: None.

### **General**

1. Bidders are hereby advised that information from bid documents which are not received from the sources listed in the Invitation for Bids is not legitimate and the bidder accepts full responsibility for any differences. RMF Engineering, Inc. has not authorized the scanning of their documents. Bidders should be aware that the plans are copyrighted and any unlawful use is subject to legal action. Bidders are further advised that the purchase and/or use of partial bid documents is not recommended and bidder will be responsible for any discrepancies which might have been avoided had a full set of documents been reviewed.
2. Bid closing date is scheduled for August 15, 2013 at 2:00pm at University of South Carolina, 743 Green Street, Conference Room 53, Columbia, SC 29208. The clock located in room 53 will be the official clock and used to determine bid closing. Late Bids will not be accepted as responsive.
3. Last day for addenda shall be August 9, 2013, 2:00 PM. All addenda will be posted to the USC purchasing website as listed on the SE-310. All addenda shall be acknowledged on the bid form.

### **Clarifications**

1. Question: Do the existing VAV Boxes being removed have hot water coils?  
Answer: No. The existing system operates in a dual duct arrangement; one hot, one cold.
2. Question: Does the concealed circular low pressure supply ductwork branch run outs have to be spiral lockseam duct?  
Answer: Yes. Provide as specified.
3. Question: Will Thermaflex MKE flexible duct be acceptable for low pressure duct run outs?  
Answer: Flex duct is acceptable with a maximum length of 6'-0" as shown.
4. Question: Does any of the medium & low pressure supply or return duct get lined?

Answer: Please refer to the plans and specifications for further information. The supply and return air duct will not be lined, but there are transfer ducts that are required to be lined.

5. Question: Is the medium pressure supply ductwork all rectangular?  
Answer: Please refer to the plans and specifications for further information.

### **Substitutions**

1. Request: Spec. Section 233110 – Dampers by Pottorff  
  
Answer: Pottorff is accepted as an approved manufacturer. Being approved as a manufacturer does not waive or preclude any and all performance, warranty or specific requirements listed within the specification or drawings unless specifically noted in the Addendum. Contractor may proceed with approved substitutions providing the Contractor assumes full responsibility for, and makes, at his own expense, any changes or adjustments in construction or connection with other work that may be required by the substitution of such materials, equipment or methods. Only manufacturers and products meeting the specification requirements and listed in the specifications or included in the Addendum shall be approved for the project. In the event of any adverse decisions by the A/E no claim of any sort shall be made or allowed against the Owner or A/E.
  
2. Request: Spec. Section 230530-2.4 – Balancing Valves by Nexus  
Answer: Nexus is accepted as an approved manufacturer. Being approved as a manufacturer does not waive or preclude any and all performance, warranty or specific requirements listed within the specification or drawings unless specifically noted in the Addendum. Contractor may proceed with approved substitutions providing the Contractor assumes full responsibility for, and makes, at his own expense, any changes or adjustments in construction or connection with other work that may be required by the substitution of such materials, equipment or methods. Only manufacturers and products meeting the specification requirements and listed in the specifications or included in the Addendum shall be approved for the project. In the event of any adverse decisions by the A/E no claim of any sort shall be made or allowed against the Owner or A/E.
  
3. Request: Spec. Section 233110-2.6 – Medium Spiral Ductwork by EHG  
Answer: EHG is accepted as an approved manufacturer. Being approved as a manufacturer does not waive or preclude any and all performance, warranty or specific requirements listed within the specification or drawings unless specifically noted in the Addendum. Contractor may proceed with approved substitutions providing the Contractor assumes full responsibility for, and makes, at his own expense, any changes or adjustments in construction or connection with other work that may be required by the substitution of such materials, equipment or methods. Only manufacturers and products meeting the specification requirements and listed in the specifications or included in the Addendum shall be approved for the project. In the event of any adverse decisions by the A/E no claim of any sort shall be made or allowed against the Owner or A/E.
  
4. Request: Spec Section 237300 – Outdoor Central Air Handling Unit by ClimateCraft

Answer: ClimateCraft is accepted as an approved manufacturer. Being approved as a manufacturer does not waive or preclude any and all performance, warranty or specific requirements listed within the specification or drawings unless specifically noted in the Addendum. Contractor may proceed with approved substitutions providing the Contractor assumes full responsibility for, and makes, at his own expense, any changes or adjustments in construction or connection with other work that may be required by the substitution of such materials, equipment or methods. Only manufacturers and products meeting the specification requirements and listed in the specifications or included in the Addendum shall be approved for the project. In the event of any adverse decisions by the A/E no claim of any sort shall be made or allowed against the Owner or A/E.

**Revisions to Project Manual**

<u>Item</u>	<u>Title and Revision</u>
1.	None.

**Revisions to Drawings**

<u>Item</u>	<u>Title and Revision</u>
1.	None.

END OF ADDENDUM NO. 2