

Video Production – Fire Protection  
Williams Brice Stadium  
Columbia, South Carolina

### Mechanical Addendum

June 1, 2012


NOTE: The following amendments, additions, and deletions shall be made to the Construction Documents and Contract Documents. Insofar as those documents are at variance with this Addendum, this Addendum shall govern.

### Drawings

- | <u>Item No.</u> | <u>Description</u>   |
|-----------------|--|
| 1.              | <u>Revision:</u> Reference Drawing FP-1. On note 4 under “Notes to Sheet” delete the requirement to protect above the ceiling of the rack room with the clean agent system. This would also apply to any references in the specifications or elsewhere on the plan.  |
| 2.              | <u>Clarification:</u> Reference Drawing FP-1. On note 5 under “Notes to Sheet” the tank size indicated is to give the contractor some reference point of what size system will be required. It will ultimately be the successful contractor’s responsibility to calculate the required amount of agent and associated tank size.   |
| 3.              | <u>Clarification:</u> Reference Drawing FP-1. The raised floor is a 12” space from the floor slab to the raised floor. The new ACT ceiling is anticipated to be 10’-0” from the floor slab to the ceiling grid, leaving a 9’-0” ceiling height in the rack room. The height to the structure above from the finished floor varies, but on average is approximately 14’-0”. |
| 4.              | <u>Clarification:</u> Reference Drawing FP-1. The owner is performing the general contracting work in this area. No reflected ceiling plan is available and the successful contractor will need to coordinate with the owner for grid layouts.   |
| 5.              | See attached sign in sheet from the pre-bid conference.  |

END OF ADDENDUM

Attachment



University of South Carolina  
W. B. S. Videoboard Installation – Fire Protection for Control Room  
Project Number: H27-6089-MJ-C  
Non-Mandatory Pre-Bid Conference  
May 30, 2012 @ 11:00 AM, 743 Greene Street, Columbia, SC 29208, Conf. Room 53

ATTENDEE'S NAME

COMPANY NAME & MAILING ADDRESS

Ann Derrick  
Kay Keisler

USC  
743 Greene Street  
Columbia, SC 29208

PHONE#

FAX#

EMAIL

Todd Swygert

Swygert & Associates, Ltd.  
P.O. Box 11686  
Columbia, SC 29211

PHONE# (803) 791-9300

FAX# (803) 791-0830

EMAIL todd@swygert-associates.com

JEFF DAVIS

USC ATHLETICS

801 LINCOLN ST.  
Columbia, SC

PHONE# 803-777-0459

FAX# 803-576-9299

EMAIL jeffd@mailbox.sc.edu

PHONE#

FAX#

EMAIL

Make sure to include your company name on this form and list it the same as if you were submitting a bid to USC. Please print clearly.