

**SECTION 00 9113
ADDENDUM NUMBER 3**

PARTICULARS

- 1.01 DATE: AUGUST 29, 2014
- 1.02 PROJECT: UNIVERSITY OF SOUTH CAROLINA - CRF DM SOM CLINICAL EDUCATION BLDG VAV REPLACEMENT
- 1.03 PROJECT NUMBER: STATE PROJECT #H27-6094-L, A/E #14016.01
- 1.04 OWNER: UNIVERSITY OF SOUTH CAROLINA
- 1.05 ARCHITECT: GMK ASSOCIATES, INC.

TO: PROSPECTIVE BIDDERS

- 2.01 THIS ADDENDUM FORMS A PART OF THE CONTRACT DOCUMENTS AND MODIFIES THE BIDDING DOCUMENTS DATED 7/31/2014 , WITH AMENDMENTS AND ADDITIONS NOTED BELOW.
- 2.02 ACKNOWLEDGE RECEIPT OF THIS ADDENDUM IN THE SPACE PROVIDED IN THE BID FORM. FAILURE TO DO SO MAY DISQUALIFY THE BIDDER.
- 2.03 THIS ADDENDUM CONSISTS OF 1 PAGE:

CHANGES TO THE PROJECT MANUAL

3.01 SECTION 15810 - DUCTS

- A. Revise Paragraph 3.03.B to read:
 - "B. Ductwork Pressure Class:
 - 1. Medium Pressure Supply Duct: 4 inch
 - 2. Low Pressure Supply Duct (downstream of VAV boxes): 2 inch"

CLARIFICATIONS

- 4.01 THE MECHANICAL SYSTEM UTILIZES THE CHASE AS A RETURN AIR PLENUM. THE CEILING PLENUM IS OPEN TO THE CHASE AND 22X22 RETURN GRILLES WITH ELBOWS ARE SPECIFIED TO GET THE RETURN AIR FROM THE SPACE INTO THE CEILING PLENUM BACK TO THE CHASE.

END OF ADDENDUM NUMBER 3