

ADDENDUM NUMBER ONE

for

**University of South Carolina
DM12 Humanities CR Elevators/Machine Room**

Project No.: U-787-14-3

State Permanent Improvement Project No.: H27-6100-H

COLUMBIA, SOUTH CAROLINA

PREPARED BY:

The Boudreaux Group 1330 Lady Street, Columbia, SC 29201

DATE OF ISSUE: June 10 2015

TO: ALL BIDDERS OF RECORD, CONSULTANTS, OWNER:

The following items shall take precedence over the drawings and specifications for the above named project and shall become a part of the contract documents. Where any item called for in the specifications, or indicated on the drawings, is not supplemented hereby, the original requirements shall remain in effect. Where any original item is amended, voided or superseded hereby, the provisions of such item not specifically amended, voided or superseded shall remain in effect.

CONTRACTOR SHALL ACKNOWLEDGE RECEIPT OF ADDENDUM.

This addendum consists of 2 pages and the following attachments: Pre-bid Sign-in Sheet

I. General:

1. Last day for questions: June 16, 2015 @ 12:00pm
2. Last Addendum: June 18, 2015 @ 2:00pm

II. Architectural:

Drawings

Item No. Description

3. Revision: Reference Drawing A1.1_R1: Provide (2) 30" x 30" 1 ½ Fire Rated Access Door to be located in the new east wall of the Elevator Equipment Room enclosure. Exact location to be provided in field by Architect. Panel to be 16 gauge cold rolled steel frame and 20 gauge galvanized steel door with continuous piano hinge. Provide self latching tool-key operated latch with automatic panel closer. Finish to be white powder coat.

USC DM12 Humanities CR Elevator/Machine Room

Addendum Number One

Page 1 of 2

Specifications

Item No. Description

1. Revision: Reference Section 140000 – Geared Traction Elevator Alterations
 - A. Change the HP or KW of the required AC drive motors from their calculated value to the current value as recommended by the controller manufacturer.
 - B. Retain the existing GAL MOVFR door operators in lieu of providing new.
 - C. Remove all references to an "Alternate bid" designation in the specification that were not all previously removed for the requirement that Auxiliary Car Stations were to be provided. These stations are part of the base bid.
 - D. Remove the requirement that the car speed was to be increased from the current 250 fpm to 350 fpm.
 - E. Add a machine re-conditioning section which requires changing gear box and drive seals and providing new gear box oil etc.
 - F. Delete any reference to completion schedule or liquidated damages.

END OF ADDENDUM

**University of South Carolina
Pre Bid Sign In Sheet
Columbia, South Carolina**

Project Name: USC DM12 Humanities CR Elevators/Machine Room
Project Number: H27-6100-H
Pre Bid Date & Time: June 9, 2015 at 10:00 am

| SWMBE Contractor | Name | Company Name | Address | Phone # | Email |
|------------------|-----------------|-------------------------|--|------------------------------|---------------------------------|
| S W M B E | DAW HORT | DAW'S HEATING & AIR LLC | 521 OLD ORANGE ROAD LEXINGTON SC | 803-520-7575 | DAW'S HEATING_AIR@M510.COM |
| S W M B E | Chase Hoskinson | Otis Elevator | 101 Lowndes Blvd, Columbia | 704-438-3847 | Chase.Hoskinson@otis.com |
| S W M B E | Jim Williams | OTIS Elevator | 101 Corporate Blvd Suite 105 West Columbia | 912-604-0116 | Jones.Williams@OTIS.COM |
| S W M B E | Chris Ferguson | USC Facilities | 743 Greene St Cdn. SC 29208 | 803-777-8569 | C Ferguson@fac. sc.edu |
| S W M B E | Wayne Wright | Oracle Elevator | 519 Shafter Drive Charlotte, NC 28206 | 803-900-0642 704-533-7629 | Wayne.Wright@oracleelevator.com |
| S W M B E | Juanana Brooks | USC | 743 Greene St Columbia SC | 803-917-3596 | jbrooks@fac. sc.edu |
| S W M B E | LIM STEEL | BOURBONNEAU GROUP | 1530 LADY ST. Columbia, SC | 799-0247 | lsteel@bourbonnaugroup.com |
| S W M B E | | | | | |
| S W M B E | | | | | |

***By signing this sheet you agree to receive information electronically.