

University of South Carolina
Wardlaw/Drayton Hall Fire Alarm Replacement
Project Number: H27-I851
Project Manager: Pete Fisher

Addendum Number One (1)

DATE: March 11, 2015

FROM: Aimee B. Rish, Procurement Specialist

TO: All Bidders

The following items add to, modify, clarify, or otherwise alter the Drawings and/or specifications and will become a part of the Contract Documents. Where a portion of the Drawings and/or specifications is added to, modified, clarified, or otherwise altered, the portion not so affected shall remain. Bidder shall include all effects that these items may have on his proposal.

Clarifications

1. The attendance sheet from the non-mandatory pre bid meeting is attached.
2. Bidders were reminded to acknowledge all addenda and have bids delivered to 743 Greene St. prior to bid opening. Late bids will not be opened.
3. The contractor is required to work in an occupied building that requires coordination with class and event schedule. No fraternization with students, staff, or faculty.
4. Contractor to avoid hazardous materials and any associated work will be provided by USC.
5. Fire Alarm Sheet FA-5 (11 of 11), Key Note 6, third sentence, should be revised to state the following: "The ATI RTU System will be provided by the USC Police/Security Department and installed..."
5. Fire Alarm Specification 16750, Section 1.1, D, 3rd sentence, should be revised to state the following: "The ATI communications signal system method and equipment procurement shall be provided by the USC Police/Security Department, and the installation..."
7. Fire Alarm Specification 16750, Section 2.11, A, 1, should be revised to state the following: "The RTU, manufactured by ATI Systems, Inc., and UL Listed for intended service, along with the associated antenna, is to be provided by the USC Police/Security Department, and installed, inspected and tested by the fire alarm installation contractor."

Attachments

Pre bid Conference Sign In-Sheet

END OF ADDENDUM Number One (1)



University of South Carolina Pre Bid Conference Sign In Sheet
Columbia, SC

Project Name, Number & Project Manager: Wardlaw/Drayton Hall Fire Alarm Replacement/H27-1851/Pete Fisher
Pre Bid Conference Date & Time: March 3, 2015 10AM-Canteen

Name	Company	Address	Phone #	Email
Chloe Williams	DNB Electric	310 Cedar Creek Dr Lexington, SC 29072	803-381-2296	Chuck @ DNB Electric.com
Todd Foster	Jsc systems	3529 Ironhorse Dr St. 105 Ladson, SC 29456	843-416-1042	t.foster@jscsystems.net
Aimee Rish	USC procurement	743 Greene St. 29308	803-777-2261	anish@usc.sc.edu
Troy Nelson	USE Energy	743 Greene St Columbia, 29308	803-777-4674	tnelson@usc.edu
Hannah Homet	USE Procurement	743 Greene St 29308	803-777-9994	hkhomet@usc.edu
KUERT MAREE	MSS FIRE & SECURITY		704-341-3132	KUERT.MAREE@MSSOLUTIONS.COM
Pete Fisher	USC Facilities	743 Greene St 29308	777-9346	PFisher@usc.sc.edu

*Please make sure you list your company name as registered with LTR.
* By signing and providing your email address, you are authorizing the University of South Carolina to send you information electronically.