

ADDENDUM # 2

Date: 3/29/12

To: All Plan Holders
Ann Derrick

From: Mark Cotterill

Subject: **Addendum # 2**
University of South Carolina
Renovate Concourse Entries at Stone Stadium
Project # H27-1967

Cc: File

The following items shall take precedence over the drawings and specifications of the above named project and shall become a part of the Contract Documents. Where any item called for in the specifications or indicated on the drawings is not supplemented hereby, the original requirements shall remain in effect. Where any original item is amended, voided or superseded hereby, the provisions of such items not specifically amended, voided or superseded shall remain in effect.

1. Clarification to Detail A, Sheet L-4, 'Brick Sign Wall (Elevation)'. Delete the reference to USC Signage Standards. Signage letters shall be 5" bronze with clear-coat finish. Letters shall be in the font style 'Revival 565 BT.' The contractor shall provide a shop drawing for approval prior to installation.
2. Clarification to Detail J, Sheet L-3, 'Brick Border and Field Pavement'. All the brick pavers shall have mortared joints, not just the banding and border.
3. Clarification to Detail D, Sheet L-4, 'Brick Sign Wall (Section)'. The note referencing 'Detail A/S-4 for lettering on signage walls' should have provided reference to Detail A/L-4.
4. **BID POSTPONEMENT: The new bid opening date is Tuesday, 4/3/12, 2:00pm. Location remains the same: Facilities Management Center, 743 Greene St., Columbia, SC 29208, Conf Rm 53.**

End of Addendum # 2