



Addendum Number One

Date of Issue: 04/21/14

Project: USC LeConte Math Library Renovations
Project Number: H27-Z141

TO: ALL BIDDERS OF RECORD

This addendum modifies the Contract documents only in the manner and to the extent stated herein and shown on any accompanying drawings and will become part of the Contract Documents. Except as specified or otherwise indicated by this Addendum, all work shall be in accordance with the basic requirements of the Contract Documents.

BIDDERS SHALL ACKNOWLEDGE RECEIPT OF ADDENDUM IN THE SPACE PROVIDED ON THE BID FORM. FAILURE TO DO SO MAY CONSTITUTE A REASON TO REJECT THE BID.

This Addendum consists of four (4) pages including this document and the following:

I. Enclosures:

1. Plan Holder's List/Pre-Bid Sign-In Sheets (2 pages)

II. General Information: Questions and Answers

The pre-bid discussion items and subsequent questions were reviewed. The following points for clarification are clarified:

1. **FLOOR to FLOOR HEIGHT:** From 3rd floor level to underside of concrete beam structure is +-9'-10". There is an additional +- 0'-10" to the underside of the coffered concrete deck.

2. **REQUEST FOR SUBSTITUTIONS:** See below for Electrical Items.

3. **ADDENDA POSTING:** Any and all addenda will be posted on the USC purchasing website. It is the responsibility of the Contractor to check the website for postings. No Addenda will be issued after Tuesday, April 22 at 5p.

4. **BATTERY PACKS:** Battery packs for lighting fixture types “CE” and “DLE” may be provided without the self-test feature”.

III. Changes to the Specifications:

NOT USED

IV. Changes to the Drawings:

NOT USED.

V. Prior Approvals

Additional Acceptable Manufacturers: The following is a list of manufacturers that are approved for this project providing they can comply with the specifications and are of equal or greater quality, and function and perform like the specified products: (Note: inclusion to the list of acceptable manufacturers does not eliminate the necessity to comply with specifications. Non-compliant products will be rejected regardless of manufacturer being listed.)

Sheet E001 – Lighting Fixture Schedule:

Fixture Type A: Metalux
Fixture Type B: Metalux
Fixture Type BE: Metalux
Fixture Type C: Metalux
Fixture Type CE: Metalux
Fixture Type D1: Portfolio
Fixture Type D1E: Portfolio
Fixture Type D2: Portfolio
Fixture Type F: Metalux
Fixture Type X: Sure-Lites

END OF ADDENDUM ONE

University of South Carolina - Upstate
Spartanburg, South Carolina

Project Name: LeConte Math Library Renovation
 Project Number: H27-2141
 Pre Bid Date & Time: April 15, 2014 @ 10 am

Name	Company Name	Address	Phone #	Email
Lee Bodenbaugh	Core Construction	PO Box 2156 West Columbia, SC 29171	791-6788	lee@coreconstructionsc.com
Greg Tyler	Tyler Const,	433 Rabon Rd. P.O. Box 25037 Columbia, SC 29224	865-1404 865-1415 (F)	gt Tyler@tyler-construction.com
DAN HOOP	DAN'S HEAT TIE LLC,	521 OLD ORANGEBOURG RD L-2-X - SC 29073	803-530-7525	DAN'S HEAT TIE AIR@MSN.COM,
Nick R. PIZZUTI	PIZZUTI BIDES LLC	1901 AUGUSTA HWY LEX, SC 29072	803- 957-5522	rbnick@windstreet.net
Jay DeRouge	MINOTEN ENGINEERING	PO Box 368 White Rock, SC 29177	803-781-1930	ESTIMATE@MINOTENENGINEERINGSC.COM
GARY FRIEDMAN	CULUM INC	3325 Pacific ST N. Charleston, SC 29418	843-576 2670	Bids@CULUMINC.COM
JASON ROUSE	HAMMER CONSTRUCTION	765 HAWORTH CIRCLE WY COLUMBIA 29209	803-782-2333	JASUN@HAMMERLLC.COM
Blake Bowman	Pyramid Cont,	1108 YKTS lane TMD, SC 29063	732-2050	wade@pyramidcontracting.ca
W CAMPBELL	COMPASS	1329 STATE ST CAMPB, SC 29033	705-0838	Wcampbell@compass-spartanburg.com

