

ADDENDUM NUMBER ONE

for

SWIM TEAM LOCKER ROOM RENOVATIONS REBID
UNIVERSITY OF SOUTH CAROLINA
COLUMBIA, SOUTH CAROLINA

DATE OF ISSUE: June 12, 2014

TO: ALL BIDDERS OF RECORD

This Addendum is issued pursuant to the Conditions of the Contract and is hereby made part of the Contract Documents. The addendum serves to clarify, revise, and supersede information in the Project Manual, the Drawings, and previously issued Addenda. The Bidder shall acknowledge receipt of this Addendum in the appropriate space on the Bid Form. Failure to do so may subject the Bidder to disqualification. A list of attachments, if any, is part of this document.

BIDDER SHALL ACKNOWLEDGE RECEIPT OF ADDENDUM IN THE SPACE PROVIDED ON THE BID FORM. FAILURE TO DO SO MAY CONSTITUTE AN INFORMALITY IN THE BID.

This addendum consists of 2 page plus the following attachments:

June 11, 2014 Pre-Bid sign in sheet
SK-A-1

A. GENERAL:

Item No. Description

1. See the attached list of attendees from June 11, 2014, Pre-Bid meeting.

B. CHANGES TO TECHNICAL SPECIFICATIONS AND DRAWINGS:

SPECIFICATIONS

Item No. Description

N/A

DRAWINGS

Item No. Description

1. **Revision:** See Sheet D1.1 First Floor Demolition Plan and attached Sketch SK-A-1. Add the following note to the Keynotes – Demolition Plan as indicated on SK-A-1, “26. ASSUME PARTIAL MUD BED TO BE DEMOLISED. VERIFY IN FIELD.” Note locations as shown on SK-A-1.

2. **Revision:** See Sheet A8.1 Finish Plans and Schedules, Comments. Delete the following: “9. “DAC” CEILING CANOPIES ARE INCLUDED IN ALTERNATE NO. 1.” Add the following: “9. NOT USED.”
3. **Revision:** See Sheet A8.1 Finish Plans and Schedules, Comments. At note 1. “PAINT ALL CEILING SURFACES, EXPOSED DUCTS AND CONDUITS, P-1.” Add the following “,TYPICAL AT ALL EXPOSED CEILINGS. SEE A2.1 FIRST FLOOR REFLECTED CEILING PLAN.”
4. **Revision:** See Sheet A8.1 Finish Plans and Schedules. Vestibule 136J shall be RSF-1as scheduled in the Finish Schedule. Revise 1/A8.1 First Floor Plan to show RSF-1 at Room Vestibule 136J.

END OF ADDENDUM