




MEDIA THIRD FLOOR



ELECTRICAL FIRE ALARM PLAN - 3RD FLOOR
 SCALE: 1/8" = 1'-0"


- NOTES:**
- GENERAL: REUSE EXISTING DEVICE LOCATIONS WHERE NOTED ON E2.1, WHERE POSSIBLE.
 - INSTALL FLEX CONDUIT IN EXISTING HOLLOW STUD WALLS WHERE POSSIBLE TO CONCEAL SURFACE MOUNTED WIREMOLD. USE OF SURFACE WIREMOLD WILL NEED TO BE APPROVED PER INSTALLATION. REFERENCE DETAILS H4/E0.1 FOR WIREMOLD INSTALLATION.
 - EXISTING FIRE ALARM PULL STATIONS ARE TYPICALLY INSTALLED GREATER THAN 48" AFF, LOWER NEW DEVICE BOX TO THE APPROPRIATE HEIGHT, PER DETAIL J/E0.1, AND REPAIR WALL AS REQUIRED. PROVIDE A FINISHED METAL COVER FOR EXISTING BOX, WITH BEVELED EDGES, PAINTED TO MATCH SURROUNDING AREAS.

REVISION	DATE	BY
A ISSUE FOR REVIEW	1/4/13	JDV
B FINAL ISSUE FOR REVIEW	2/8/13	JDV