

University of South Carolina  
Project Name: Rebid USC Lancaster Bradley Hall Physics Lab Upgrades  
Project Number: 19010.01  
State Project Number: H37-9519  
Project Manager: Lee Miller

Addendum Number 3

Date: August 22, 2019

From: GMK Associates

To All Bidders:

The following items add to, modify, clarify or otherwise alter the Drawings and/ or specifications and will be a part of the Contract Documents. Where a portion of the Drawings and/or specification is added to, modified or otherwise altered, the portion not so affected shall remain. Bidder shall include all effects that these items may have on this proposal. Acknowledge receipt of this Addendum in the space provided in the Bid Form. Failure to do so may subject Bidder to disqualification.

CHANGES TO PROJECT MANUAL:

1. none

CHANGES TO THE DRAWINGS:

1. none

CLARIFICATIONS:

1. Q: The base bid is to patch the epoxy and the alternate is to fill level & re-coat epoxy. My question is for the alternate does this mean to remove the existing coating and install 2 coats of Tnemec 238 or just go over the existing coating and add an extra coat?
  - a. A: The existing coating should remain in place and prepped as described in the specification for the installation of the new coating. The contractors should contact the vendor listed in the specification or the vendor of their choice for additional guidance on floor prep. The supplied coating must meet or exceed the requirements of the basis of design.

End of Addendum Three