



**CAROLINA ENGINEERING
CONSULTANTS, INC.**

P.O. Box 294
Beaufort, SC 29901

(843) 322-0553
(843) 322-0556 Fax

To: All Holders of Record of Contract Documents

From: Jeff P. Ackerman, P.E.

Date: October 21, 2015

**Subject: Addendum Number 2 - USC Salkehatchie - Carolina Theater Parking
Lot Construction - Project Number: H38-I322**

Acknowledge receipt of this addendum by inserting its number and date in the Bid Form. Failure to do so may subject bidder to disqualification. This addendum forms a part of the Contract Documents.

QUESTION

Can we use concrete instead of asphalt for the parking area?

ANSWER

It is acceptable to substitute concrete paving for the areas that were proposed to be asphalt.

The "6" Concrete Paving Detail" on page six of the drawings shall be followed if the bidder decides to substitute concrete paving for the asphalt paving. Additionally, the Contractor shall note in his bid that this substitution was made.

END OF ADDENDUM NUMBER 2