

University of South Carolina

Project Name: USC Lancaster Hubbard Hall Roof Replacement

Project Number: H37-9519 50003346-4

Project Manager: Lee Miller

Addendum Number 3

Date: August 29, 2019

From: Rob Lyon, Lyon & Associates

To All Bidders:

The following items add to, modify, clarify or otherwise alter the Drawings and/ or specifications and will be a part of the Contract Documents. Where a portion of the Drawings and/or specification is added to, modified or otherwise altered, the portion not so affected shall remain. Bidder shall include all effects that these items may have on this proposal.

Acknowledge receipt of this Addendum in the space provided in the Bid Form. Failure to do so may subject Bidder to disqualification.

General/Clarification:

- 1) The bid date and time for this project has been changed to September 5th at 2:30 PM.
- 2) Please disregard all references to FM Global RoofNav requirements for the roof assembly.
- 3) Please disregard reference to the use of asphalt to adhere roof insulation. Low-rise foam insulation adhesive is the only adhesive approved for use to adhere insulation and the horizontal portions of the roof membrane.

END OF ADDENDUM #3