



U N I V E R S I T Y O F
SOUTH CAROLINA

AMENDMENT NO.4

TO: ALL VENDORS

FROM: Lana Widener

SUBJECT: USC-BVB-1811-LW

Furnish, Deliver and Install On a Temporary Basis Three Generator Power Systems and Back-Up Cooling to Provide Temporary Power for USC's Data Center

DATE: October 5, 2010

This Addendum No. 4 modifies the Invitation for Bid only in the manner and to the extent as stated herein.

Item One: **Section III. Scope of Work / Specifications, Section Air Cooled Chiller, PART 1 – GENERAL, 1.1, currently reads:**

1.1 Provide (1) 100 ton and (1) 60 ton portable packaged air conditioners for rental by the University of South Carolina. The units shall match the available power source voltage and phase; verify in field before releasing order.

Replace **Section III. Scope of Work / Specifications, Section Air Cooled Chiller, PART 1 – GENERAL, 1.1 to read:**

1.1 Contractor is to provide upward to 160 ton portable total chilling capacity / packaged air conditioners for rental by the University of South Carolina provided all electrical demands are met per the electrical specs, paragraph 1.2, b and c.
The units shall match the available power source voltage and phase; verify in field before releasing order.

Item Two: Add the following sentence at the beginning of **Section III. Scope of Work / Specifications, Section Air Cooled Chiller, PART 1 – GENERAL, 1.8 PERFORMANCE:**

Should the vendor use the 100 ton air conditioner and the 60 ton air conditioner units then they to have the following capabilities:

Item Three: Service Personnel are to be on site when the units are energized. The date and times are currently scheduled for 8 hours on 12/20 and 16 hours on 12/27.



BIDDER SHALL ACKNOWLEDGE RECEIPT OF ADDENDUM NO. 4 IN THE SPACE PROVIDED BELOW

AND RETURN IT **WITH THEIR BID RESPONSE**. FAILURE TO DO SO MAY SUBJECT BID TO REJECTION.

Authorized Signature

Firm

Date