



U N I V E R S I T Y O F  
**SOUTH CAROLINA**

**AMENDMENT NO. 1**

**TO: ALL VENDORS**

**FROM: Lana Widener**

**SUBJECT: USC-IFB-1559-LW  
Furnish, Deliver and Install New Eaton 15KV Switchgear**

**DATE: November 24, 2009**

---

This Amendment No. 1 modifies the Invitation for Bid only in the manner and to the extent as stated herein.

**ITEM ONE: See Page Two**

**ITEM TWO: QUESTIONS RECEIVED AFTER DEADLINE WERE CONSIDERED BY THE UNIVERSITY. A DECISION WAS MADE TO ANSWER THE QUESTIONS BASED UPON THEIR VALUE TO THE SUCCESS OF THE SOLICITATION, SEE PAGE TWO FOR QUESTIONS AND ANSWERS.**

---

BIDDER SHALL ACKNOWLEDGE RECEIPT OF AMENDMENT NO. 1 IN THE SPACE PROVIDED BELOW

AND RETURN IT **WITH THEIR BID RESPONSE**. FAILURE TO DO SO MAY SUBJECT BID TO REJECTION.

\_\_\_\_\_  
Authorized Signature

\_\_\_\_\_  
Firm

\_\_\_\_\_  
Date

## PAGE TWO

### ITEM ONE:

#### THE FOLLOWING QUESTIONS WERE RECEIVED FOR FURTHER CLARIFICATION FROM VENDOR A

- Question #1** There are 2ea. Electroswitch Series 24 Breaker Control Switches listed in both breaker compartments. Is this necessary? If so, Why would do you need 2 switches to control 1 breaker?
- Answer #1** Yes, two breakers – one for each compartment.
- Question #2** There are several styles of Electroswitch Series 24 Breaker Control Switches. Is there any particular criteria.
- Answer #2** No.
- Question #3** Are equivalent LED lighting assemblies acceptable? We typically use Allen Bradley LED indicating lights.
- Answer #3** Equivalent LED is acceptable.
- Question #4** CT's are stated as single ratio, standard accuracy. The ratio is never stated. I was planning on quoting 1200:5 SCV type.
- Answer #4** The 1200:5 SCV type is approved.
- Question #5** What do you mean by a "24" rear extension OSA" under Special Items?
- Answer #5** 24 inch (24") is a rear extension – it provides space.
- Question #6** Could you please describe what is required by "Communication wiring-Incom"?
- Answer #6** It is to communicate with the metasys system.
- Question #7** How many lights are required per breaker cabinet?
- Answer #7** If it is "indication lights" they are required on both breakers. If it is "interior" or "to see by" lights, they are not required.
- Question #8** What is VW-1 type wiring?
- Answer #8** VW-1 type wiring is "standard" wiring.
- Question #9** Does the spare VT tray assembly mount in the section above the PT drawer and CPT drawer? Do I need to include 2 spare PT's in the spare drawer for a total of 4ea. PT's (2 connected and 2 not connected)?
- Answer #9** See Attachment A (the drawing) in the original solicitation package.