



U N I V E R S I T Y O F
SOUTH CAROLINA

AMENDMENT NO. 1

TO: ALL VENDORS

FROM: Damon Hightower

**SUBJECT: USC-IFB-1764-DH
Remove, Dispose, Furnish, Deliver and Install an Indoor Telescopic Bleacher Seating System at the
University of South Carolina Salkehatchie – Walterboro Campus**

DATE: August 16, 2010

This Amendment No. 1 modifies the Invitation for Bid only in the manner and to the extent as stated herein.

ITEM ONE: QUESTIONS RECEIVED WERE CONSIDERED BY THE UNIVERSITY. A DECISION WAS MADE TO ANSWER THE QUESTIONS BASED UPON THEIR VALUE TO THE SUCCESS OF THE SOLICITATION.

ITEM TWO: ADD – (Page 12) III. SCOPE OF WORK / SPECIFICATIONS – DESIGN SPECIFICATIONS REQUIREMENTS

BIDDER SHALL ACKNOWLEDGE RECEIPT OF AMENDMENT NO. 1 IN THE SPACE PROVIDED BELOW AND RETURN IT WITH THEIR BID RESPONSE. FAILURE TO DO SO MAY SUBJECT BID TO REJECTION.

Authorized Signature

Firm

Date

ITEM ONE:

THE FOLLOWING QUESTIONS WERE RECEIVED FROM VENDORS:

Question #1 I do not see any reference to who is approved, am I to assume that if you can meet the specification, you are allowed to bid this project. The company that we intend to bid is Irwin Telescopic.

Answer #1 Yes, you will be able submit a bid with a manufacturer's design which meets or exceeds the specifications. Per the instructions listed in the bid solicitation on page #15, the submission will require a set of manufacturer's shop drawings in which specifications can be reviewed.

ITEM TWO: ADDITION - III. SCOPE OF WORK / SPECIFICATIONS – DESIGN SPECIFICATIONS REQUIREMENTS

Please add the following clause to the Design Specifications Requirements on page 12-13 of USC-IFB-1764-DH.

- O. The steel supporting frame design structure must include a minimum of 10 steel column supports per each 87foot bleacher bank.