



U N I V E R S I T Y O F
SOUTH CAROLINA

AMENDMENT NO.2 TO SOLICITATION

TO: ALL VENDORS
FROM: Kevin Sanders, Procurement Manager
SUBJECT: SUBJECT: SOLICITATION NUMBER: USC-IFB-2264-KS
Generator/Transfer Switch

DATE: July 2nd, 2012

This Amendment **No.2** modifies the Request for quote only in the manner and to the extent as stated herein.

BIDDER SHALL ACKNOWLEDGE RECEIPT OF AMENDMENT **NO.2** IN THE SPACE PROVIDED BELOW AND RETURN IT WITH THEIR BID RESPONSE. FAILURE TO DO SO MAY SUBJECT BID TO REJECTION.

Authorized Signature

Name of Offeror

Date

Question #1

- 263212-2,1.5 Informational Submittals:
 - o A. Manufacturers Seismic Qualification Certification: Refers to Section 260548 which is not part of the IFB.

Answer #1

1. The generator shall be designed to meet seismic category C, seismic response coefficient (Cs) of 0.109, and Seismic Importance Factor (I) of 1.25. Per specifications, the manufacturer shall provide a submittal certifying that it meets the seismic qualifications stated above. Per specifications, the awarded manufacturer to provide the seismic mounting information so the pad can be prepared for installation and proper bolts provided by others.

Question #2

- 263213-9, 2.8 Outdoor Generator-Set enclosure:
 - o 3. Space heater. Not normally required in our local ambient.
 - o 7. Thermal insulation. Not normally required in our ambient.
 - o C.2. Automatic Dampers. Very expensive vs. the generator set cost and not normally used on this size generator set in our ambient.
 - o D. Convenient outlets. Best supplied by the installing contractor.

Answer #2

These Items are deleted

Question #3

- 263600-1, 1.4 Informational Submittals:
 - o B. Manufacturers Seismic Qualification Certification: Refers to Section 260548 which is not part of the IFB.

Answer #3

Refer to Answer #1

Question #4

- Is installation by others or by this vendor?

Answer #4

Bidder will set the unit in place, hook-up and terminations to unit by others, Bidder will perform start-up as per the specifications.