



**U N I V E R S I T Y O F**  
**SOUTH CAROLINA**

**AMENDMENT NO. 1**

**TO:** ALL VENDORS  
**FROM:** Lana Widener  
**SUBJECT:** USC-IFB-2336-LW  
Furnish and Deliver Zwick Valves  
**DATE:** November 6, 2012

---

This Amendment No. 1 modifies the Invitation for Bid only in the manner and to the extent as stated herein.

**ITEM ONE: VENDOR QUESTIONS**

**QUESTION:**

this pertains to the Zwick specification for 2 each 12" #A1-0300X-ZA11AG... On page #10 of this job requirement, it has "Scope Of Work" with the model numbers, sizes and number of bolts. Under this, the 12" #A1 Zwick valve states 12 bolt. The Zwick model number designates #150 ANSI flanged and 12 bolts for 12" lines up with #150 ANSI flanged. But, under that, the "Valve Schedule" has Vault #D7-1D with this same 12" #A1-0300X-ZA11AG but states 16 bolts, which would be #300 ANSI flanged going by the number of bolts? (Zwick model number is for #150, not #300 flanged)

**ANSWER:**

The correct Bolts for Vault D7-1D is 12.

---

BIDDER SHALL ACKNOWLEDGE RECEIPT OF AMENDMENT NO. 1 IN THE SPACE PROVIDED BELOW AND RETURN IT **WITH THEIR BID RESPONSE**. FAILURE TO DO SO MAY SUBJECT BID TO REJECTION.

\_\_\_\_\_  
Authorized Signature

\_\_\_\_\_  
Firm

\_\_\_\_\_  
Date