



U N I V E R S I T Y O F
SOUTH CAROLINA

AMENDMENT NO. 4

TO: ALL VENDORS
FROM: Lana Widener
SUBJECT: USC-IFB-2561-LW
East Quad Interior Painting
DATE: March 17, 2014

This Amendment No. 4 modifies the Invitation for Bid only in the manner and to the extent as stated herein.

ITEM ONE: VENDOR QUESTIONS

QUESTION:

In response to the addendum 3, we have two questions resulting from the addendum.

1. The item 7 states that Cove base is to be removed and replaced. Is this all cove base in the entire building? Hallways? Rooms?
What base type and brand do they want put back? This is a question that needs clarified prior to the bid due to the amount of work that is added without description
2. Do the windows get painted? It refers to the stuck windows but there are factory finished windows. Please clarify if any windows get painted or are the referring to something else with the stuck windows.

ANSWER:

1. Yes, the 4" rubber base will need to be removed and replaced throughout (stairwells, corridors and apartments) with Johnsonite 120' rolls in 63 Burnt Umber.
2. The windows will not be painted. The interior sill, apron, decorative wood cornice and surrounding areas will be painted.

BIDDER SHALL ACKNOWLEDGE RECEIPT OF AMENDMENT NO. 4 IN THE SPACE PROVIDED BELOW AND RETURN IT **WITH THEIR BID RESPONSE**. FAILURE TO DO SO MAY SUBJECT BID TO REJECTION.

Authorized Signature

Firm

Date