



UNIVERSITY OF
SOUTH CAROLINA

AMENDMENT NO. 5

TO: ALL VENDORS
FROM: Lana Widener
SUBJECT: USC-IFB-2561-LW
East Quad Interior Painting
DATE: March 19, 2014

This Amendment No. 5 modifies the Invitation for Bid only in the manner and to the extent as stated herein.

- ITEM ONE: EXTENSION FOR DEADLINE FOR BIDS, DUE DATE**
The date for deadline to submit bids has been extended to March, 24, 2014, 10:00 AM
- ITEM TWO: EXTENSION FOR AWARD POSTING**
The date for Posting the Award has been extended to March 25, 2014.
- ITEM THREE: CLARIFICATION**
Item Six from Amendment No. 3 stated the Bid Schedule was Item One, please note that it was actually Item FIVE in Amendment No. 3.
- ITEM FOUR: VENDOR QUESTIONS**
VENDOR A
QUESTION #1:
Questions from Addendum #3.
1) "VENDOR B QUESTION
Specification 1.04
A6. Mentions preparation of ceiling grid.
Q. Is ACT ceiling structure to be painted?
ANSWER
As an option, USC Housing would like to replace ceiling grid and ACT, see Revised Bid Schedule (Item One)."
- a) Where is the ceiling located?
b) What is the spec on the ceiling?
- ANSWER #1**
a) **1st Floor:**
110, 131, 132, 133, 134 and 138
2nd Floor:
231, 232, 233, 234, 237, 238, 239, 240 and 261

3rd Floor:

331, 332, 333, 334, 335, 336, 337, 338, 339 and 340

4th Floor:

431, 432, 433, 434, 435, 437, 438 and 440

5th Floor:

535, 536, 537, 538, 539 and 540

b) Armstrong, 2x2 Cirrus Profiles Classic Step Tegular in white.

QUESTION #2

"ITEM SEVEN: CONTRACTOR MUST REMOVE AND REPLACE EXISTING COVE BASE AS A PART OF SCOPE OF WORK, SECTION III."

- a) Are we reusing the existing base?
- b) If new do you have a spec for the new base?
- c) Where do we quote the base?

ANSWER #2

- a) No, refer to amendment # 4, answer 1.
- b) refer to amendment # 4, answer 1.
- c) All material is to be included in line items 1-4 in the Bid Schedule.

BIDDER SHALL ACKNOWLEDGE RECEIPT OF AMENDMENT NO. 5 IN THE SPACE PROVIDED BELOW AND RETURN IT **WITH THEIR BID RESPONSE**. FAILURE TO DO SO MAY SUBJECT BID TO REJECTION.

Authorized Signature

Firm

Date