



U N I V E R S I T Y O F  
**SOUTH CAROLINA**

AMENDMENT NO.2 TO SOLICITATION

TO: ALL VENDORS  
FROM: Kevin Sanders, Procurement Manager  
SUBJECT: SOLICITATION NUMBER: USC-IFB-2595-KS  
Fencing

DATE: April 30<sup>th</sup> 2014

---

This Amendment **No.2** modifies the Invitation for Bid only in the manner and to the extent as stated herein.

**Foundation thickness for 350 Wayne Street is believed to be 6".  
THIS IS NOT CONFIRMED.**

**Vendor questions/Answers**

---

BIDDER SHALL ACKNOWLEDGE RECEIPT OF AMENDMENT **NO 2** IN THE SPACE PROVIDED BELOW AND RETURN IT WITH THEIR BID RESPONSE. FAILURE TO DO SO MAY SUBJECT BID TO REJECTION.

\_\_\_\_\_  
Authorized Signature

\_\_\_\_\_  
Name of Offeror

\_\_\_\_\_  
Date

Question

#1: The drawing we got yesterday is different than the one in the bid package. This effects the quantities of rolling gates, etc. Which do we use?

Answer

New drawing are included in Amendment #1. The drawing included with the original solicitation package are no longer valid

Question

#2; Is there an spec for the line post on this project?

Answer

2 ½ inch line Posts Schedule 20