



UNIVERSITY OF  
**SOUTH CAROLINA**

**AMENDMENT NO. 2**

**TO:** ALL VENDORS  
**FROM:** Lana Widener  
**SUBJECT:** USC-IFB-2840-LW  
**Rental of Two 400 Ton Air Cooled Chillers for North Energy Facility**  
**DATE:** June 9, 2015

---

This Amendment No. 2 modifies the Invitation for Bid only in the manner and to the extent as stated herein.

**ITEM ONE: VENDOR QUESTION**

We are curious if the pricing needs to include connection of the chillers to the existing chilled water system and not just start up and disconnection of booth chillers as stated in the scope?

**ANSWER**

Yes, it needs to include connecting the chillers to the temporary chilled water taps located outside of the energy facility.

**Note:** These taps were installed specifically for the connection of rental chillers to the chilled water loop.

---

BIDDER SHALL ACKNOWLEDGE RECEIPT OF AMENDMENT NO. 2 IN THE SPACE PROVIDED BELOW AND RETURN IT **WITH THEIR BID RESPONSE**. FAILURE TO DO SO MAY SUBJECT BID TO REJECTION.

---

Authorized Signature

---

Firm

---

Date