



U N I V E R S I T Y O F  
**SOUTH CAROLINA**

AMENDMENT NO. 6 TO SOLICITATION

TO: ALL VENDORS

FROM: Charles Johnson, Procurement Manager

SUBJECT: SOLICITATION NUMBER: USC-RFP-1761-CJ

**SOLAR PV INSTALLATION AT USC BASEBALL STADIUM**

DATE: June 29, 2010

---

This Amendment **No. 6** modifies the Request For Proposals only in the manner and to the extent as stated herein.

---

BIDDER SHALL ACKNOWLEDGE RECEIPT OF AMENDMENT **NO. 6** IN THE SPACE PROVIDED BELOW AND RETURN IT WITH THEIR BID RESPONSE. FAILURE TO DO SO MAY SUBJECT BID TO REJECTION.

\_\_\_\_\_  
Authorized Signature

\_\_\_\_\_  
Name of Offeror

\_\_\_\_\_  
Date

During the Site Visit, a question was asked about placement of a disconnect for feeding power back into the SCE&G grid - here is our response:

**“USC is not concerned about feeding power back into the SCE&G grid since the potential power to be generated in this case is so small. The likely scenario is that the power generated by the solar panels will be tied into light fixtures, a vendor booth or some other application at the stadium. Bidders should not include costs of equipment to tie back into the main power grid.”**



