



U N I V E R S I T Y O F  
**SOUTH CAROLINA**

AMENDMENT NO.2 TO SOLICITATION

TO: ALL VENDORS

FROM: Kevin Sanders, Procurement Manager

SUBJECT: SUBJECT: SOLICITATION NUMBER: USC-RFQ-2239-KS  
Light Poles/Lamp Assemblies

DATE: June 11<sup>th</sup>, 2012

---

This Amendment **No.2** modifies the Request for Quote only in the manner and to the extent as stated herein.

---

BIDDER SHALL ACKNOWLEDGE RECEIPT OF AMENDMENT **NO. 2** IN THE SPACE PROVIDED BELOW AND RETURN IT WITH THEIR BID RESPONSE. FAILURE TO DO SO MAY SUBJECT BID TO REJECTION.

---

Authorized Signature

---

Name of Offeror

---

Date

## **Vendor Question #1**

*Could you identify the job site where these products will be used and also – could you provide a part number for the pole from a fixture schedule?*

### **Answer #1**

#### **Description for pole and fixture # P1, Quantity of 10**

Pole mounted lighting fixture

Lamps: Type – MH, Wattage – 150, Quantity – 1, Color Temp – 3500 deg K

Ballast: Type - Electronic pulse start, Quantity – 1

Voltage: 277V

Input Wattage: 168

Mounting: Pole

Remarks: Mounted on 14' pole, single head with IES cut off option. Provide pole by Sternberg, Catalog # 5214FP5 with custom finish RAL # 7026

Manufacturer: Sternberg # MS805B-3-R05-FHC-150PSMH-MED-277-CA-CM-RAL7026

#### **Description for pole and fixture # P2, Quantity of 5**

Pole mounted lighting fixture

Lamps: Type – MH, Wattage – 150, Quantity – 1, Color Temp – 3500 deg K

Ballast: Type - Electronic pulse start, Quantity – 1

Voltage: 208V, 1 phase

Input Wattage: 168

Mounting: Pole

Remarks: Mounted on 14' pole, single head with IES cut off option. Provide pole by Sternberg, Catalog # 5214FP5 with custom finish RAL # 7026

Manufacturer: Sternberg # MS805B-3-R05-FHC-150PSMH-MED-208-CA-CM-RAL7026

Notes: All components are to be shipped to the site at 1300 Heyward St, Columbia, SC 29208. Either USC or contractor will off-load. Coordinate shipment with USC. Package aluminum poles for shipping accordingly to ASTM B660.