



U N I V E R S I T Y O F
SOUTH CAROLINA

AMENDMENT NO.2 TO SOLICITATION

TO: ALL VENDORS

FROM: Kevin Sanders, Procurement Manager

SUBJECT: SUBJECT: SOLICITATION NUMBER: USC-RFQ-2260-KS
Repair/replace/paint damaged gypsum board soffits and fiberglass
columns

DATE: June 26th, 2012

This Amendment **No.2** modifies the Request for Quote only in the manner and to the extent as stated herein.

Vendor Questions

BIDDER SHALL ACKNOWLEDGE RECEIPT OF AMENDMENT **NO. 2** IN THE SPACE PROVIDED BELOW AND RETURN IT WITH THEIR BID RESPONSE. FAILURE TO DO SO MAY SUBJECT BID TO REJECTION.

Authorized Signature

Name of Offeror

Date

Question 1

Is there a specific paint product or replacement board that you want used for this project?

Answer 1

The exterior soffits are to be a regular type ½ inch thick Glass Mat Gypsum Sheathing Board, using a minimum 2" wide glass mesh tape on joints using Manufac. setting type compound on joints and apply an even skim coat to entire surface of sheathing including joints before applying primer. Color on plans state it was to be painted white-white and it is a textured pain

Large Columns colors are listed as Subtly Natural by Rose Talbert