



U N I V E R S I T Y O F
SOUTH CAROLINA

AMENDMENT NO. 2

TO: ALL VENDORS
FROM: Lana Widener
SUBJECT: USC-RFQ-2471-LW
Furnish and Deliver Mechanical Equipment for Equestrian Farm
DATE: July 5, 2013

This Amendment No. 2 modifies the Request for Quotes only in the manner and to the extent as stated herein.

ITEM ONE: DUE DATE HAS BEEN EXTENDED TO JULY 9, 2013, NO CHANGE IN TIME.

ITEM TWO: VENDOR QUESTION

Question #1

Concerning Line Item 2, Mitsubishi units. The type of control must be selected by the end-user. Can your people advise us which type of indoor control they want? See page 22 of the RFQ for available options.

Additionally, no interconnecting line set length is called out. The line set connects the indoor section to the outdoor section and a length of control cable that connects the indoor unit to the outdoor unit will be required as well.

Answer:

- 1. Controller shall be wired wall mounted 7 day programmable thermostat by Mitsubishi.**
 - 2. Contractor shall provide line set capable of a minimum of 35 linear feet for each line. This line length is based on the locations currently shown on the drawings**
-

BIDDER SHALL ACKNOWLEDGE RECEIPT OF AMENDMENT NO. 2 IN THE SPACE PROVIDED BELOW AND RETURN IT **WITH THEIR BID RESPONSE**. FAILURE TO DO SO MAY SUBJECT BID TO REJECTION.

Authorized Signature

Firm

Date