



U N I V E R S I T Y O F  
**SOUTH CAROLINA**

AMENDMENT NO. 3

**TO:** ALL VENDORS  
**FROM:** Lana Widener  
**SUBJECT:** USC-RFQ-2471-LW  
Furnish and Deliver Mechanical Equipment for Equestrian Farm  
**DATE:** July 5, 2013

---

This Amendment No. 3 modifies the Request for Quotes only in the manner and to the extent as stated herein.

**ITEM ONE: VENDOR QUESTION**

**Question #1**

One other question concerning the Mitsubishi units: is your specifier calling for the disconnect between the indoor unit and the outdoor unit, the outdoor unit disconnect, or both? I surmise the disconnect that breaks the connection between the indoor and outdoor unit is the one they are seeking, but just want to be sure.

**Answer:**

**The factory disconnects are at the High Voltage power connection to the units. Indoor and Outdoor**

---

BIDDER SHALL ACKNOWLEDGE RECEIPT OF AMENDMENT NO. 3 IN THE SPACE PROVIDED BELOW AND RETURN IT **WITH THEIR BID RESPONSE**. FAILURE TO DO SO MAY SUBJECT BID TO REJECTION.

\_\_\_\_\_  
Authorized Signature

\_\_\_\_\_  
Firm

\_\_\_\_\_  
Date