



U N I V E R S I T Y O F  
**SOUTH CAROLINA**

**AMENDMENT NO. 3**

**TO:** ALL VENDORS  
**FROM:** Lana Widener  
**SUBJECT:** USC-RFQ-2600-LW  
Furnish and Deliver New Exhaust Fans  
**DATE:** May 7, 2014

---

This Amendment No. 3 modifies the Request for Quotes only in the manner and to the extent as stated herein.

**ITEM ONE: CORRECTION IN AMENDMENT #2, 2<sup>ND</sup> QUESTION**

**Question Reads:**

Also we will need to know the location of the fan, whether stainless steel or aluminum construction is needed, and the rotation of the fan; either clockwise or counterclockwise.

**ANSWER**

**Amendment No. #2 should have read: Refer to Item No. 4 above**

For clarification, the answer is included in its entirety below:

**CODE:** 133717 – 001 – 1

**HP:** 1

**Max RPM:** 2800

**MODEL:** SMB - 8

**MAX TEMP:** 150

**ROTATION:** Clockwise

**FAN WHEEL:** Aluminum

---

BIDDER SHALL ACKNOWLEDGE RECEIPT OF AMENDMENT NO. 3 IN THE SPACE PROVIDED BELOW AND RETURN IT **WITH THEIR BID RESPONSE**. FAILURE TO DO SO MAY SUBJECT BID TO REJECTION.

\_\_\_\_\_  
Authorized Signature

\_\_\_\_\_  
Firm

\_\_\_\_\_  
Date