



UNIVERSITY OF SOUTH CAROLINA

AMENDMENT NO. 1

TO: ALL VENDORS
FROM: Lana Widener
SUBJECT: USC-RFQ-2609-LW
DATE: May 22, 2014

This Amendment No. 1 modifies the Request for Quotes only in the manner and to the extent as stated herein.

ITEM ONE: ADD PART 2 PRODUCTS TO SECTION 16496G – SEE ATTACHED PAGE 16596G-3

ITEM TWO: **VENDOR QUESTIONS:**

Question:

Is the transfer switch, 1200 amp at 208, a 3 or 4 pole switch.

Answer:

Three pole switch.

Question:

Does it have a bypass isolation.

Answer:

Yes, see specifications.

BIDDER SHALL ACKNOWLEDGE RECEIPT OF AMENDMENT NO. 1 IN THE SPACE PROVIDED BELOW AND RETURN IT **WITH THEIR BID RESPONSE**. FAILURE TO DO SO MAY SUBJECT BID TO REJECTION.

Authorized Signature

Firm

Date

PART 2 PRODUCTS

2.01 MANUFACTURERS

- A. Caterpillar
- B. Cummins-ONAN
- C. Kohler
- D. The listing of specific manufacturers above does not imply acceptance of their products that do not meet the specified ratings, features and functions. Manufacturers listed above are not relieved from meeting these specifications in their entirety. Products in compliance with the specification and manufactured by others not named will be considered only if pre-approved by the engineer ten (10) days prior to bid date.

Note to Spec Writer:

Select from the table below to fill in the data required for 2.02A

· Note to Spec. Writer – Insert data in blanks