



UNIVERSITY OF
SOUTH CAROLINA

AMENDMENT TO SOLICITATION

Amendment No. 1

DATE: March 11, 2015

TO: ALL VENDORS

FROM: Mac Stiles, Procurement Manager

SOLICITATION NUMBER: USC-IFB-2771-MS

DESCRIPTION: Furnish & Deliver Restroom Lighting Fixtures

This **Amendment No. 1** modifies the **Request for Quotation** only in the manner and to the extent as stated herein.

Vendor Question

Q: I have a question for the 6" LED Shower Downlight with Non-Conductive Trim. Do you need 31W or 980 Lumens, because 31W will give you more lumens than 980?

A: **We need a minimum 980 delivered lumens. 31 watts was based on the specification data for the Gotham fixture. Some of the other manufacturers could provide the same delivered lumens for less wattage, and that is acceptable.**

Bidder shall acknowledge receipt of Amendment No. 1 in the space provided below and return it with their bid response. Failure to do so may subject bid to rejection.

Authorized Signature

Name of Offeror

Date