



AMENDMENT TO SOLICITATION

Amendment No. 1

DATE: May 22, 2015

TO: ALL VENDORS

FROM: Mac Stiles, Procurement Manager

SOLICITATION NUMBER: USC-RFQ-2808-MS

DESCRIPTION: Provide Flooring Application at Housing Facilities Warehouse

This Amendment No. 1 modifies the Request For Quotation only in the manner and to the extent as stated herein.

ITEM ONE – Amend Specifications as follows:

Specifications

- Prime with **one-quarter inch (1/4")** epoxy hi-build primer.
- Finish color should be in the gray color spectrum, so as to provide contrast for red and/or yellow lines and other markings that will be added to the surface at a later date. Exact color will be determined after contract award.
- One year standard written warranty to include normal wear and tear should be provided after award.

ITEM TWO – Questions from Vendors

Question 1: Will we be able to achieve 480v single phase power to run our equipment for surface preparation?

Answer 1: There are only 240V power sources in the warehouse. No 480V power sources are able to be supplied by the University for this contract.

Bidder shall acknowledge receipt of Amendment No. 1 in the space provided below and return it with their bid response. Failure to do so may subject bid to rejection.

Authorized Signature

Name of Offeror

Date