



UNIVERSITY OF
SOUTH CAROLINA

AMENDMENT TO SOLICITATION

Amendment No. 1

DATE: May 25, 2015

TO: ALL VENDORS

FROM: Mac Stiles, Procurement Manager

SOLICITATION NUMBER: USC-RFQ-2809-MS

DESCRIPTION: Furnish and Install Storage Racks at Housing Facilities Warehouse

This **Amendment No. 1** modifies the **Request For Quotation** only in the manner and to the extent as stated herein.

ITEM ONE – Revise Specifications

Specifications

- Six (6) Total Racks – see Diagram
 - 2 each: 6’ wide x 72’ long x 14’ high w/ 3 horizontal shelves
 - ❖ *Reduced from 10’ to 6’ wide (Rows 1 & 6 on Diagram)*
 - 2 each: 12’ wide x 48’ long x 14’ high w/ 3 horizontal shelves
 - ❖ *Reduced from 3 to 2 each (Rows 2 & 5 on Diagram)*
 - 1 each: 10’ wide x 48’ long x 14’ high w/ 3 horizontal shelves
 - ❖ *Reduced from 12’ to 10’ wide (Row 3 on Diagram)*
 - 1 each: 10’ wide x 36’ long x 14’ high w/ 4 horizontal shelves
 - ❖ *No change (Row 4 on Diagram)*
- Shelving to be adjustable for full height of rack shaft. Spacing between shelves to be determined during install.
- Wire decking on shelves with minimum 3,000# capacity.
- Provide 12” Yellow Post Protectors for all corner posts.
- All racks must be new; used racks will not be accepted.
- Consistency in color, design, and shape is preferred.

ITEM TWO – Vendor Question

Q: Is the weight require for wire decking of 3000 lbs correct?

A: Yes.

Bidder shall acknowledge receipt of Amendment No. 1 in the space provided below and return it with their bid response. Failure to do so may subject bid to rejection.

Authorized Signature

Name of Offeror

Date