



AMENDMENT NO. 1 TO SOLICITATION

DATE: April 17, 2019
TO: ALL VENDORS
FROM: Tracy Fountain
SUBJECT: USC-RFQ-3451-TF-REBID
DESCRIPTION: **Furnish, Deliver and Install Valcom – Support Security Alert System at USC Beaufort Campus**

This Amendment No. 1 modifies the Request for Quotes only in the manner and to the extent as stated herein.

Item #1 Change Deadline for Quote to April 26, 2019 at 10:00 am

Item #2 Questions and Answers from Vendors

Question: There should be a type number, spec number or cat. number for the 30hp. Similar to the 50hp info.

Answer: Removing the existing drive equipment from Permalite Cooling Towers and install new TEI DirecDrive™ motors (30 HP, 412 rpm, Model FL2882), motor support beams and VFDs (NEMA 1 enclosure).

OFFERORS SHALL ACKNOWLEDGE RECEIPT OF AMENDMENT NO. 1 IN THE SPACE PROVIDED BELOW AND RETURN IT WITH THEIR QUOTE RESPONSE. FAILURE TO DO SO MAY SUBJECT QUOTE TO REJECTION.

Authorized Signature

Name of Offeror

Date