

University of South Carolina  
**Longstreet Theatre Shutter Replacement**

1300 Greene Street, Columbia, South Carolina

State Project Number: H27-Z147-A

April 26, 2016

**ADDENDUM NO. 2**

This addendum forms a part of the Contract documents and modifies the original Bidding Documents and any previous Addenda as noted below. Acknowledge receipt of this Addendum in the space provided in the Bid Form. Failure to do so may subject Bidder to disqualification.

**MODIFICATIONS TO PREVIOUS ADDENDA:**

None

**MODIFICATIONS TO PROJECT MANUAL:**

None

**MODIFICATIONS TO DRAWINGS:**

None

**ARCHITECTURAL DRAWINGS:**

None

**REQUESTED PRODUCT APPROVALS:**

None

**QUESTIONS FROM CONTRACTORS:**

1. Question: The louver blade is shown as "Nominal 1/4" x 1 3/4" Aluminum Louver", can a more standard 1/4" x 1 1/2" louver be used?  
**a. Answer: Yes, we will accept a 1/4" x 1 1/2" Aluminum Louver blade.**
2. Question: Would the Owner be willing to use slightly different size stile and rail components that are more standard?  
**Answer: No, provide all stile and rail components as shown on the drawings.**
3. Question: Would the Owner be willing to use a composite material for any components?  
**a. Answer: No, all components of the system are to be Aluminum.**

**END OF ADDENDUM NO. 2**